



**SYNERGY INSTITUTE OF ENGINEERING & TECHNOLOGY, DHENKANAL
DEPARTMENT OF ELECTRICAL ENGINEERING**

Name of Faculty : SHAKTI SHANKAR PATI

Degree : B. TECH.

Branch : ELECTRICAL ENGINEERING

Semester : 5TH

Name of Subject : ELECTRICAL POWER TRANSMISSION AND DISTRIBUTION

Subject Code :REL5C001

Subject Credit : 3

UNIT – I

TRANSMISSION LINE PARAMETERS

1. INTRODUCTION:

Electric power can be transmitted or distributed either by means of underground cables or by overhead lines. The under-ground cables are rarely used for power transmission due to two main reasons. Firstly, power is generally transmitted over long distances to load centers. Obviously, the installation costs for underground transmission will be very heavy. Secondly, electric power has to be transmitted at high voltages for economic reasons. It is very difficult to provide proper insulation† to the cables to withstand such higher pressures. Therefore, as a rule, power transmission over long distances is carried out by using overhead lines. With the growth in power demand and consequent rise in voltage levels, power transmission by overhead lines has assumed considerable importance

An overhead line is subjected to uncertain weather conditions and other external interferences. This calls for the use of proper mechanical factors of safety in order to ensure the continuity of operation in the line. In general, the strength of the line should be such so as to provide against the worst probable weather conditions. In this chapter, we shall focus our attention on the various aspects of mechanical design of overhead lines.

2. MAIN COMPONENTS OF OVERHEAD LINES:

An overhead line may be used to transmit or distribute electric power. The successful operation of an overhead line depends to a great extent upon the mechanical design of the line. While constructing an overhead line, it should be ensured that mechanical strength of the line is such so as to provide against the most probable weather conditions. In general, the main components of an overhead line are:

- i. Conductors which carry electric power from the sending end station to the receiving end station.
- ii. Supports which may be poles or towers and keep the conductors at a suitable level above the ground.
- iii. Insulators which are attached to supports and insulate the conductors from the ground.
- iv. Cross arms which provide support to the insulators.

Miscellaneous items such as phase plates, danger plates, lightning arrestors, anti-climbing wires etc.

The continuity of operation in the overhead line depends upon the judicious choice of above components. Therefore, it is profitable to have detailed discussion on them.

CONDUCTOR MATERIALS:

The conductor is one of the important items as most of the capital outlay is invested for it. Therefore, proper choice of material and size of the conductor is of considerable importance. The conductor material used for transmission and distribution of electric power should have the following properties:

- i. high electrical conductivity.
- ii. high tensile strength in order to withstand mechanical stresses.
- iii. low cost so that it can be used for long distances.
- iv. low specific gravity so that weight per unit volume is small.

All above requirements are not found in a single material. Therefore, while selecting a conductor material for a particular case, a compromise is made between the cost and the required electrical and mechanical properties.

2.1.1 COMMONLY USED CONDUCTOR MATERIALS:

The most commonly used conductor materials for over-head lines are copper, aluminium, steel-cored aluminium, galvanized steel and cadmium copper. The choice of a particular material will depend upon the cost, the required electrical and mechanical properties and the local conditions.

All conductors used for overhead lines are preferably stranded* in order to increase the flexibility. In stranded conductors, there is generally one central wire and round this, successive layers of wires containing 6, 12, 18, 24 wires. Thus, if there are n layers, the total number of individual wires is $3n(n+1) + 1$. In the manufacture of stranded conductors, the consecutive layers of wires are twisted or spiraled in opposite directions so that layers are bound together.

1. Copper:

Copper is an ideal material for overhead lines owing to its high electrical conductivity and greater tensile strength. It is always used in the hard drawn form as stranded conductor.

Although hard drawing decreases the electrical conductivity slightly yet it increases the tensile strength considerably.

Copper has high current density i.e., the current carrying capacity of copper per unit of X-sectional area is quite large. This leads to two advantages. Firstly, smaller X-sectional area of conductor is required and secondly, the area offered by the conductor to wind loads is reduced. Moreover, this metal is quite homogeneous, durable and has high scrap value.

There is hardly any doubt that copper is an ideal material for transmission and distribution of electric power. However, due to its higher cost and non-availability, it is rarely used for these purposes. Now-a-days the trend is to use aluminium in place of copper.

2. Aluminium:

Aluminium is cheap and light as compared to copper but it has much smaller conductivity and tensile strength. The relative comparison of the two materials is briefed below :

(i) The conductivity of aluminium is 60% that of copper. The smaller conductivity of aluminium means that for any particular transmission efficiency, the X-sectional area of conductor must be larger in aluminium than in copper. For the same resistance, the diameter of aluminium conductor is about 1.26 times the diameter of copper conductor.

The increased X-section of aluminium exposes a greater surface to wind pressure and, therefore, supporting towers must be designed for greater transverse strength. This often requires the use of higher towers with consequence of greater sag.

(ii) The specific gravity of aluminium (2.71 gm/cc) is lower than that of copper (8.9 gm/cc). Therefore, an aluminium conductor has almost one-half the weight of equivalent copper conductor. For this reason, the supporting structures for aluminium need not be made so strong as that of copper conductor.


(iii) Aluminium conductor being light, is liable to greater swings and hence larger cross-arms are required.

(iv) Due to lower tensile strength and higher co-efficient of linear expansion of aluminium, the sag is greater in aluminium conductors.

Considering the combined properties of cost, conductivity, tensile strength, weight etc., aluminium has an edge over copper. Therefore, it is being widely used as a conductor material. It is particularly profitable to use aluminium for heavy-current transmission where the conductor size is large and its cost forms a major proportion of the total cost of complete installation.

3. Steel cored aluminium:

Due to low tensile strength, aluminium conductors produce greater sag. This prohibits their use for larger spans and makes them unsuitable for long distance transmission. In order to increase the tensile strength, the aluminium conductor is reinforced with a core of galvanized steel wires. The composite conductor thus obtained is known as steel cored aluminium and is abbreviated as



(aluminium conductor steel reinforced).

Steel-cored aluminium conductor consists of central core of galvanized steel wires surrounded by a number of aluminium strands. Usually, diameter of both steel and aluminium wires is the same. The X-section of the two metals are generally in the ratio of 1 : 6 but can be modified to 1 : 4 in order to get more tensile strength for the conductor. Fig. 8.1 shows steel cored aluminium conductor having one steel wire surrounded by six wires of aluminium. The result of this composite conductor is that steel core takes greater percentage of

Mechanical strength while aluminium strands carry the bulk of current. The steel cored aluminium conductors have the following advantages:

The reinforcement with steel increases the tensile strength but at the same time keeps the composite conductor light. Therefore, steel cored aluminium conductors will produce smaller sag and hence longer spans can be used.

Due to smaller sag with steel cored aluminium conductors, towers of smaller heights can be used.

4. Galvanized steel:

Steel has very high tensile strength. Therefore, galvanized steel conductors can be used for extremely long spans or for short line sections exposed to abnormally high stresses due to climatic conditions. They have been found very suitable in rural areas where cheapness is the main consideration. Due to poor conductivity and high resistance of steel, such conductors are not suitable for transmitting large power over a long distance. However, they can be used to advantage for transmitting a small power over a small distance where the size of the copper conductor desirable from economic considerations would be too small and thus unsuitable for use because of poor mechanical strength.

5. Cadmium copper:

The conductor material now being employed in certain cases is copper alloyed with cadmium. An addition of 1% or 2% cadmium to copper increases the tensile strength by about 50% and the conductivity is only reduced by 15% below that of pure copper. Therefore, cadmium copper conductor

can be useful for exceptionally long spans. However, due to high cost of cadmium, such conductors will be economical only for lines of small X-section i.e., where the cost of conductor material is comparatively small compared with the cost of supports.

LINESUPPORTS:


The supporting structures for overhead line conductors are various types of poles and towers called line supports. In general, the line supports should have the following properties :

- (i) High mechanical strength to withstand the weight of conductors and wind loads etc.
- (ii) Light in weight without the loss of mechanical strength.
- (iii) Cheap in cost and economical to maintain.
- (iv) Longer life.
- (v) Easy accessibility of conductors for maintenance.


The line supports used for transmission and distribution of electric power are of various types including wooden poles, steel poles, R.C.C. poles and lattice steel towers. The choice of supporting structure for a particular case depends upon the line span, X-sectional area, line voltage, cost and local conditions.

1. Wooden poles: These are made of seasoned wood (sal or chir) and are suitable for lines of moderate X-sectional area and of relatively shorter spans, say up to 50 metres. Such supports are cheap, easily available, provide insulating properties and, therefore, are widely used for distribution purposes in rural areas as an economical proposition. The wooden poles generally tend to rot below the ground level, causing foundation failure. In order to prevent this, the portion of the pole below the ground level is impregnated with preservative compounds like creosote oil. Double pole structures of the 'A' or 'H' type are often used (See Fig. 8.2) to obtain a higher transverse strength than could be economically provided by means of single poles.

The main objections to wooden supports are : (i) tendency to rot below the ground level (ii) comparatively smaller life (20-25 years) (iii) cannot be used for voltages higher than 20 kV (iv) less mechanical strength and (v) require periodical inspection.



2. Steel poles: The steel poles are often used as a substitute for wooden poles. They possess greater mechanical strength, longer life and permit longer spans to be used. Such poles are generally used for distribution purposes in the cities. This type of supports need to be galvanised or painted in order to prolong its life. The steel poles are of three types viz., (i) rail poles (ii) tubular poles and




(iii) rolled steel joints.

3. RCC poles: The reinforced concrete poles have become very popular as line supports in recent years. They have greater mechanical strength, longer life and permit longer spans than steel poles. Moreover, they give good outlook, require little maintenance and have good insulating properties. Fig. 8.3 shows R.C.C. poles for single and double circuit. The holes in the poles facilitate the climbing of poles and at the same time reduce the weight of line supports.

The main difficulty with the use of these poles is the high cost of transport owing to their heavy weight. Therefore, such poles are often manufactured at the site in order to avoid heavy cost of transportation.

4. Steel towers: In practice, wooden, steel and reinforced concrete poles are used for distribution purposes at low voltages, say upto 11 kV. However, for long distance transmission at higher voltage, steel towers are invariably employed. Steel towers have greater mechanical strength, longer



life, can withstand most severe climatic conditions and permit the use of longer spans. The risk of interrupted service due to broken or punctured insulation is considerably reduced owing to longer spans. Tower footings are usually grounded by driving rods into the earth. This minimizes the lightning troubles as each tower acts as a lightning conductor.

Fig. 8.4 (i) shows a single circuit tower. However, at a moderate additional cost, double circuit tower can be provided as shown in Fig. 8.4 (ii). The double circuit has the advantage that it ensures continuity of supply. In case there is breakdown of one circuit, the continuity of supply can be maintained by the other circuit.

INSULATORS:

The overhead line conductor should be supported on the poles or towers in such a way that currents from conductors do not flow to earth through supports i.e., line conductors must be properly insulated from supports. This is achieved by securing line conductors to supports with the help of insulators. The insulators provide necessary insulation between line conductors and supports and thus prevent any leakage current from conductors to earth. In general, the insulators should have the following desirable properties:

- i. High mechanical strength in order to withstand conductor load, wind load etc.
- ii. High electrical resistance of insulator material in order to avoid leakage current to earth.
- iii. High relative permittivity of insulator material in order that dielectric strength is high.
- iv. The insulator material should be non-porous, free from impurities and cracks otherwise the permittivity will be lowered.
- v. High ratio of puncture strength to flashover.

The most commonly used material for insulators of overhead line is porcelain but glass, steatite and special composition materials are also used to a limited extent. Porcelain is produced by firing at a high temperature a mixture of kaolin, feldspar and quartz. It is stronger mechanically than glass, gives less trouble from leakage and is less affected by changes of temperature.

3. SERIES PARAMETERS OF TRANSMISSION LINES:

Overhead transmission lines and transmission towers are a common sight in rural India. The transmission towers are usually made of steel and are solidly erected with a concrete base. The three-phase conductors are supported by the towers through insulators. The conductors are usually made of aluminum or its alloys. Aluminum is preferred over copper as an aluminum conductor is lighter in weight and cheaper in cost than copper conductor of the same resistance.

The conductors are not straight wires but strands of wire twisted together to form a single conductor to give it higher tensile strength. One of the most common conductor is aluminum conductor, steel reinforced (ACSR). The cross sectional view of such a conductor is shown in Fig. 1.2. The central core is formed with strands of steel while two layers of aluminum strands are put in the outer layer. The other type of conductors that are in use are all aluminum conductor (AAC), all aluminum alloy conductor (AAAC), aluminum conductor, alloy reinforced (ACAR).




Fig-A: ACSR conductor

Cross sectional view of an ACSR conductor

LINE RESISTANCE:

It is very well known that the dc resistance of a wire is given by

$$R_{dc} = \frac{\rho l}{A} \Omega \quad (1.1)$$

where ρ is the resistivity of the wire in $\Omega\text{-m}$, l is the length in m and A is the cross sectional area in m^2 .

Unfortunately however the resistance of an overhead conductor is not the same as that given by the above expression. When alternating current flows through a conductor, the current density is not uniform over the entire cross section but is somewhat higher at the surface. This is called the skin effect and this makes the ac resistance a little more than the dc resistance. Moreover in a stranded conductor, the length of each strand is more than the length of the composite conductor. This also increases the value of the resistance from that calculated in (1.1).

Finally the temperature also affects the resistivity of conductors. However the temperature rise in metallic conductors is almost linear in the practical range of operation and is given by

$$\frac{R_2}{R_1} = \frac{T + t_1}{T + t_2} \quad (1.2)$$

where R_1 and R_2 are resistances at temperatures t_1 and t_2 respectively and T is a constant that depends of the conductor material and its conductivity. Since the resistance of a conductor cannot be determined accurately, it is best to determine it from the data supplied by the manufacturer.

INDUCTANCE:

INDUCTANCE OF A SINGLE-PHASE LINE:

Consider two solid round conductors with radii of r_1 and r_2 as shown in Fig. 1.5. One conductor is the return circuit for the other. This implies that if the current in conductor 1 is I then the current in conductor 2 is $-I$. First let us consider conductor 1. The current flowing in the conductor will set up flux lines. However, the flux beyond a distance $D + r_2$ from the center of the conductor links a net current of zero and therefore does not contribute to the flux linkage of the circuit. Also at a distance less than $D - r_2$ from the center of conductor 1 the current flowing through this conductor links the flux. Moreover since $D \gg r_2$ we can make the following approximations

$$D + r_1 \approx D \text{ and } D - r_1 \approx D$$

Therefore from (1.12) and (1.17) we can specify the inductance of conductor 1 due to internal and external flux as

$$L_1 = \left(\frac{1}{2} + 2 \ln \frac{D}{r_1} \right) \times 10^{-7} \text{ H / m}$$




Fig. 1.5 A single-phase line with two conductors.

We can rearrange L_1 given in (1.18) as follows

$$L_1 = 2 \times 10^{-7} \left(\frac{1}{4} + \ln \frac{D}{r_1} \right) = 2 \times 10^{-7} \left(\ln e^{1/4} + \ln \frac{D}{r_1} \right) = 2 \times 10^{-7} \ln \left(\frac{D}{r_1 e^{-1/4}} \right)$$

Substituting $r_1' = r_1 e^{1/4}$ in the above expression we get

$$L_1 = 2 \times 10^{-7} \left(\ln \frac{D}{r_1'} \right) \text{ H/m} \quad (1.19)$$

The radius r_1' can be assumed to be that of a fictitious conductor that has no internal flux but with the same inductance as that of a conductor with radius r_1 .

In a similar way the inductance due current in the conductor 2 is given by

$$L_2 = 2 \times 10^{-7} \left(\ln \frac{D}{r_2'} \right) \text{ H/m} \quad (1.20)$$

Therefore the inductance of the complete circuit is

$$\begin{aligned} L &= L_1 + L_2 = 2 \times 10^{-7} \left(\ln \frac{D}{r_1'} \right) + 2 \times 10^{-7} \left(\ln \frac{D}{r_2'} \right) \\ &= 2 \times 10^{-7} \left(\ln \frac{D^2}{r_1' r_2'} \right) = 4 \times 10^{-7} \left(\ln \frac{D}{\sqrt{r_1' r_2'}} \right) \text{ H/m} \end{aligned} \quad (1.21)$$

If we assume $r_1' = r_2' = r'$, then the total inductance becomes

$$L = 4 \times 10^{-7} \left(\ln \frac{D}{r'} \right) \text{ H/m} \quad (1.22)$$

INDUCTANCE OF THREE-PHASE LINES WITH SYMMETRICAL SPACING:

Consider the three-phase line shown in Fig. 1.6. Each of the conductors has a radius of r and their centers form an equilateral triangle with a distance D between them. Assuming that the currents are balanced, we have


$$I_a + I_b + I_c = 0 \quad (1.22)$$

Also consider a point P external to the conductors. The distance of the point from the phases a , b and c are denoted by D_{pa} , D_{pb} and D_{pc} respectively.

Let us consider the flux linked by the conductor of phase- a due to a current I_a including internal flux linkages but excluding flux linkages beyond the point P . From (1.18) we get

$$\lambda_{apa} = \left(\frac{1}{2} + 2 \ln \frac{D_{pa}}{r'} \right) I_a = 2 \times 10^{-7} I_a \ln \frac{D_{pa}}{r'} \quad (1.23)$$

The flux linkage with the conductor of phase- a due to the current I_b , excluding all flux beyond the point P , is given by (1.17) as



Three-phase symmetrically spaced conductors and an external point P

$$\lambda_{apb} = 2 \times 10^{-7} I_b \ln \frac{D_{pb}}{D}$$

Similarly the flux due to the current I_c is

$$\lambda_{apc} = 2 \times 10^{-7} I_c \ln \frac{D_{pc}}{D} \quad (1.25)$$

Therefore the total flux in the phase- a conductor is

$$\lambda_a = \lambda_{apa} + \lambda_{apb} + \lambda_{apc} = 2 \times 10^{-7} \left(I_a \ln \frac{D_{pa}}{r'} + I_b \ln \frac{D_{pb}}{D} + I_c \ln \frac{D_{pc}}{D} \right) \quad (1.26)$$

The above expression can be expanded as

$$\lambda_a = 2 \times 10^{-7} \left(I_a \ln \frac{1}{r'} + I_b \ln \frac{1}{D} + I_c \ln \frac{1}{D} + I_a \ln D_{pa} + I_b \ln D_{pb} + I_c \ln D_{pc} \right) \quad (1.27)$$

From (1.22) we get

$$I_b + I_c = -I_a$$

Substituting the above expression in (1.27) we get

$$\lambda_a = 2 \times 10^{-7} \left(I_a \ln \frac{1}{r'} - I_a \ln \frac{1}{D} + I_b \ln \frac{D_{pb}}{D_{pa}} + I_c \ln \frac{D_{pc}}{D_{pa}} \right) \quad (1.28)$$

Now if we move the point P far away, then we can approximate $D_{pa} \approx D_{pb} \approx D_{pc}$. Therefore their logarithmic ratios will vanish and we can write (1.28) as

$$\lambda_a = 2 \times 10^{-7} \left(I_a \ln \frac{1}{r'} - I_a \ln \frac{1}{D} \right) = 2 \times 10^{-7} I_a \ln \frac{D}{r'} \quad (1.29)$$

Hence the inductance of phase-a is given as

$$L_a = 2 \times 10^{-7} \ln \frac{D}{r'} \quad (1.30)$$

Note that due to symmetry, the inductances of phases b and c will be the same as that of phase-a given above, i.e., $L_b = L_c = L_a$.


INDUCTANCE OF THREE-PHASE LINES WITH ASYMMETRICAL SPACING:

It is rather difficult to maintain symmetrical spacing as shown in Fig. 1.6 while constructing a transmission line. With asymmetrical spacing between the phases, the voltage drop due to line inductance will be unbalanced even when the line currents are balanced. Consider the three-phase asymmetrical spaced line shown in Fig. 1.7 in which the radius of each conductor is assumed to be r . The distances between the phases are denoted by D_{ab} , D_{bc} and D_{ca} . We then get the following flux linkages for the three phases

$$\lambda_a = 2 \times 10^{-7} \left(I_a \ln \frac{1}{r'} + I_b \ln \frac{1}{D_{ab}} + I_c \ln \frac{1}{D_{ca}} \right) \quad (1.31)$$

$$\lambda_b = 2 \times 10^{-7} \left(I_b \ln \frac{1}{r'} + I_a \ln \frac{1}{D_{ab}} + I_c \ln \frac{1}{D_{bc}} \right) \quad (1.32)$$

$$\lambda_c = 2 \times 10^{-7} \left(I_c \ln \frac{1}{r'} + I_a \ln \frac{1}{D_{ca}} + I_b \ln \frac{1}{D_{bc}} \right) \quad (1.33)$$



Three-phase asymmetrical spaced line

Let us define the following operator

$$a = e^{j120^\circ} = -\frac{1}{2} + j\frac{\sqrt{3}}{2} \quad (1.34)$$

Note that for the above operator the following relations hold

$$a^2 = e^{j240^\circ} = -\frac{1}{2} - j\frac{\sqrt{3}}{2} \text{ and } 1 + a + a^2 = 0 \quad (1.35)$$

Let us assume that the current are balanced. We can then write

$$I_b = a^2 I_a \text{ and } I_c = a I_a$$

Substituting the above two expressions in (1.31) to (1.33) we get the inductance of the three phases as

$$L_a = 2 \times 10^{-7} \ln \left(\frac{1}{r'} + \frac{a^2 \ln 1}{D_{ab}} + \frac{a \ln 1}{D_{ca}} \right) \quad (1.36)$$


$$L_b = 2 \times 10^{-7} \ln \left(\frac{1}{r'} + \frac{a \ln 1}{D_{ab}} + \frac{a^2 \ln 1}{D_{bc}} \right) \quad (1.37)$$

$$L_c = 2 \times 10^{-7} \ln \left(\frac{1}{r'} + \frac{a^2 \ln 1}{D_{ca}} + \frac{a \ln 1}{D_{bc}} \right) \quad (1.38)$$

It can be seen that the inductances contain imaginary terms. The imaginary terms will vanish only when $D_{ab} = D_{bc} = D_{ca}$. In that case the inductance will be same as given by (1.30).

TRANPOSED LINE:

The inductances that are given in (1.36) to (1.38) are undesirable as they result in an unbalanced circuit configuration. One way of restoring the balanced nature of the circuit is to exchange the positions of the conductors at regular intervals. This is called transposition of line and is shown in Fig. 1.8. In this each segment of the line is divided into three equal sub-segments. The conductors of each of the phases a, b and c are exchanged after every sub-segment such that each of them is placed in each of the three positions once in the entire segment. For example, the conductor of the phase-a occupies positions in the sequence 1, 2 and 3 in the three sub-segments while that of the phase-b occupies 2, 3 and 1. The transmission line consists several such segments.



Transposition of the Conductors

A segment of a transposed line

In a transposed line, each phase takes all the three positions. Therefore the per phase inductance is the average value of the three inductances calculated in (1.36) to (1.38). We therefore have

$$L = \frac{L_a + L_b + L_c}{3}$$

This implies

$$L = \frac{2 \times 10^{-7}}{3} \left[\ln \frac{3}{r'} + (a+a) \left(\ln \frac{1}{D_{ab}} + \ln \frac{1}{D_{bc}} + \ln \frac{1}{D_{ca}} \right) \right]$$

From (1.35) we have $a + a^2 = -1$. Substituting in the above equation we get

$$L = \frac{2 \times 10^{-7}}{3} \left[\ln \frac{3}{r'} - \ln \frac{1}{D_{ab}} - \ln \frac{1}{D_{bc}} - \ln \frac{1}{D_{ca}} \right]$$

The above equation can be simplified as

$$L = \frac{2 \times 10^{-7}}{3} \left[\ln \frac{1}{r'} - \ln \frac{1}{(D_{ab} D_{bc} D_{ca})^{1/3}} \right] = 2 \times 10^{-7} \ln \frac{(D_{ab} D_{bc} D_{ca})^{1/3}}{r'}$$

Defining the geometric mean distance (GMD) as

$$GMD = \sqrt[3]{D_{ab} D_{bc} D_{ca}}$$

equation (1.41) can be rewritten as

$$L = 2 \times 10^{-7} \ln \frac{GMD}{r'} H / m$$

Notice that is of the same form as (1.30) for symmetrical spaced conductors. Comparing these two equations we can conclude that GMD can be construed as the equivalent conductor spacing. The GMD is the cube root of the product of conductor spacings.

COMPOSITE CONDUCTORS:

So far we have considered only solid round conductors. However as mentioned at the beginning of Section 1.1 stranded conductors are used in practical transmission line. We must therefore modify the equations derived above to accommodate stranded conductors. Consider the two groups of conductors shown in Fig. 1.9. Of these two groups conductor x contains n identical strands of radius r_x while conductor y contains m identical strands of radius r_y . Conductor x carries a current I the return path of which is through conductor y. Therefore the current through conductor y is -I.




Fig. 2.6 Single-phase line consisting of two composite conductors

Since the strands in a conductor are identical, the current will be divided equally among the strands. Therefore the current through the strands of conductor x is I/n and through the strands of conductor y is $-I/m$. The total flux linkage of strand a is given by

$$\lambda_a = 2 \times 10^{-7} I \ln \left(\frac{1}{r_a} + \frac{1}{r_{ab}} + \frac{1}{r_{ac}} + \dots + \frac{1}{r_{an}} \right) \quad (1.44)$$

$$- 2 \times 10^{-7} I \ln \left(\frac{1}{r_{aa}} + \frac{1}{r_{ab}} + \frac{1}{r_{ac}} + \dots + \frac{1}{r_{am}} \right)$$

We can write (1.44) as

$$\lambda_a = 2 \times 10^{-7} I \ln \frac{\sqrt[m]{D_{aa} \cdot D_{ab} \cdot D_{ac} \dots D_{am}}}{\sqrt[n]{r_{aabac} \dots D_{an}}} \quad (1.45)$$

The inductance of the strand a is then given by

$$L_a = \frac{\lambda_a}{I} = 2 \times 10^{-7} \ln \frac{\sqrt[m]{D_{aa} \cdot D_{ab} \cdot D_{ac} \dots D_{am}}}{\sqrt[n]{r_{aabac} \dots D_{an}}} \quad (1.46)$$

In a similar way the inductances of the other conductors are also obtained. For example,

$$L_b = 2 \times 10^{-7} \ln \frac{\sqrt[m]{D_{ba} \cdot D_{bb} \cdot D_{bc} \dots D_{bm}}}{\sqrt[n]{r_{abbac} \dots D_{bn}}} \quad (1.47)$$

$$L_c = 2 \times 10^{-7} \ln \frac{\sqrt[m]{D_{ca} \cdot D_{cb} \cdot D_{cc} \dots D_{cm}}}{\sqrt[n]{r_{acc} \dots D_{cn}}}$$

The average inductance of any one of the strands in the group of conductor x is then

$$L_{av,x} = \frac{L_a + L_b + L_c + \dots + L_n}{n} \quad (1.48)$$

Conductor x is composed of n strands that are electrically parallel. Even though the inductance of the different is different, the average inductance of all of them is the same as $L_{av,x}$. Assuming that the average inductance given above is the inductances of n parallel strands, the total inductance of the conductor x is

$$L_x = \frac{L_{av,x}}{n} = \frac{L_a + L_b + L_c + \dots + L_n}{n^2} \quad (1.49)$$

Substituting the values of L_a , L_b etc. in the above equation we get

$$L_x = 2 \times 10^{-7} \ln \frac{GMD}{GMR_x} \quad (1.50)$$

where the geometric mean distance (GMD) and the geometric mean radius (GMR) are given respectively by

$$GMD = \sqrt[n]{(D_{aa} \cdot D_{ab} \cdot D_{ac} \dots D_{am}) \dots (D_{na} \cdot D_{nb} \cdot D_{nc} \dots D_{nn})} \quad (1.51)$$

$$GMR_x = \sqrt[n]{(r_{aabac} \dots D_{an}) \dots (r_{nabac} \dots D_{nn})} \quad (1.52)$$

The inductance of the conductor y can also be similarly obtained. The geometric mean radius GMR_y will be different for this conductor. However the geometric mean distance will remain the same.

BUNDLED CONDUCTORS:

So far we have discussed three-phase systems that have only one conductor per phase. However for extra high voltage lines corona cause a large problem if the conductor has only one conductor per phase. Corona occurs when the surface potential gradient of a conductor exceeds the dielectric strength of the surrounding air. This causes ionization of the area near the conductor. Corona produces power loss. It also causes interference of the communication channels. Corona manifests itself with a hissing sound and ozone discharge. Since most long distance power lines in India are either 220 kV or 400 kV, avoidance of the occurrence of corona is desirable.

The high voltage surface gradient is reduced considerably by having two or more conductors per phase in close proximity. This is called conductor bundling. The conductors are bundled in groups of two, three or four as shown in Fig. 1.10. The conductors of a bundle are separated at regular intervals with spacer dampers that prevent clashing of the conductors and prevent them from swaying in the wind. They also connect the conductors in parallel.

The geometric mean radius (GMR) of two-conductor bundle is given by

$$D_{s,2b} = \sqrt[4]{(D_s \times d)^2} = \sqrt{D_s \times d} \quad (1.53)$$

where D_s is the GMR of conductor. The GMR for three-conductor and four-conductor bundles are given respectively by


$$D_{s,3b} = \sqrt[9]{(D_s \times d \times d)^3} = \sqrt[3]{D_s \times d^2} \quad (1.54)$$

$$D_{s,4b} = \sqrt[9]{(D_s \times d \times d \times \sqrt{2}d)^4} = 1.094 \sqrt[4]{D_s \times d^3} \quad (1.55)$$

The inductance of the bundled conductor is then given by

$$L = 2 \times 10^{-7} \ln \frac{GMD}{D_{s,b}} \quad (1.56)$$

where the geometric mean distance is calculated assuming that the center of a round conductor is the same as that of the center of the bundle.



Bundled conductors: (a) 2-conductor, (b) 3-conductor and (c) 4-conductor bundles.

SHUNT PARAMETERS OF TRANSMISSION LINES

Capacitance in a transmission line results due to the potential difference between the conductors. The conductors get charged in the same way as the parallel plates of a capacitor. Capacitance between two parallel conductors depends on the size and the spacing between the conductors. Usually the capacitance is neglected for the transmission lines that are less than 50 miles (80 km) long. However the capacitance

becomes significant for longer lines with higher voltage. In this section we shall derive the line capacitance of different line configuration.

CAPACITANCE OF A STRAIGHT CONDUCTOR:

Consider the round conductor is shown in Fig. 1.11. The conductor has a radius of r and carries a charge of q coulombs. The capacitance C is the ratio of charge q of the conductor to the impressed voltage, i.e.,

$$C = \frac{q}{V} \quad (1.57)$$

The charge on the conductor gives rise to an electric field with radial flux lines where the total electric flux is equal to the charge on the conductor. By Gauss's law, the electric flux density at a cylinder of radius x when the conductor has a length of 1 m is




Fig. 4.1

Cylindrical conductor with radial flux lines.


$$D = \frac{q}{A} = \frac{q}{2\pi x} \text{ C/m}^2 \quad (1.58)$$

The electric field intensity is defined as the ratio of electric flux density to the permittivity of the medium. Therefore

$$E = \frac{q}{2\pi x \epsilon_0} \text{ V / m} \quad (1.59)$$

Now consider the straight long conductor of Fig. 1.12 that is carrying a positive charge q C/m. Let two points P_1 and P_2 be located at distances D_1 and D_2 respectively from the center of the conductor. The conductor is an equipotential surface in which we can assume that the uniformly distributed charge is concentrated at the center of the conductor. The potential difference V_{12} between the points P_1 and P_2 is the work done in moving a unit of charge from P_2 to P_1 . Therefore the voltage drop between the two points can be computed by integrating the field intensity over a radial path between the equipotential surfaces, i.e.,

$$V_{12} = \int_{D_1}^{D_2} E \, dx = \int_{D_1}^{D_2} \frac{q}{2\pi x \epsilon_0} \ln^2 \frac{D_2}{D_1} \, dx$$



CAPACITANCE OF A SINGLE-PHASELINE:

Consider the single-phase line consisting of two round conductors as shown in Fig. 1.5. The separation between the conductors is D . Let us assume that conductor 1 carries a charge of q_1 C/m while conductor 2 carries a charge q_2 C/m. The presence of the second conductor and the ground will disturb field of the first conductor. However we assume that the distance of separation between the conductor is much larger compared to the radius of the conductor and the height of the conductor is much larger than D for the ground to disturb the flux. Therefore the distortion is small and the charge is uniformly distributed on the surface of the conductor.

Assuming that the conductor 1 alone has the charge q_1 , the voltage between the conductors is

$$V_{12}(q_1) = \frac{q_1}{2\pi\epsilon_0} \ln \frac{D}{r_1} \quad (1.61)$$

Similarly if the conductor 2 alone has the charge q_2 , the voltage between the conductors is

$$V_{21}(q_2) = \frac{q_2}{2\pi\epsilon_0} \ln \frac{D}{r_2} \quad (1.62)$$

This implies that

$$V_{12}(q_2) = \frac{q_2}{2\pi\epsilon_0} \ln \frac{r_2}{D}$$

From the principle of superposition we can write

$$V_{12} = V_{12}(q_1) + V_{12}(q_2) = \frac{q_1}{2\pi\epsilon_0} \ln \frac{D}{r_1} + \frac{q_2}{2\pi\epsilon_0} \ln \frac{r_2}{D} \quad (1.63)$$

For a single-phase line $q_1 = -q_2 = q$. We therefore have

$$V_{12} = \frac{q}{2\pi\epsilon_0} \ln \frac{D}{r_1} - \frac{q}{2\pi\epsilon_0} \ln \frac{r_2}{D} = \frac{q}{2\pi\epsilon_0} \ln \frac{D^2}{r_1 r_2} \quad (1.64)$$

Assuming $r_1 = r_2 = r$, we can rewrite (1.64) as


$$V_{12} = \frac{q}{\pi\epsilon_0} \ln \frac{D}{r} \quad (1.65)$$

Therefore from (1.57) the capacitance between the conductors is given by

$$C_{12} = \frac{\pi\epsilon_0}{\ln(D/r)} \text{ F/m} \quad (1.66)$$

The above equation gives the capacitance between two conductors. For the purpose of transmission line modeling, the capacitance is defined between the conductor and neutral. This is shown in Fig. 1.13. Therefore the value of the capacitance is given from Fig. 1.13 as

$$C = 2C_{12} = \frac{2\pi\epsilon_0}{\ln(D/r)} \text{ F/m}$$




(a) Capacitance between two conductors and (b) equivalent capacitance to ground.

CAPACITANCE OF A THREE-PHASE TRANPOSED LINE:

Consider the three-phase transposed line shown in Fig. 1.14. In this the charges on conductors of phases a, b and c are q_a , q_b and q_c respectively. Since the system is assumed to be balanced we have

$$q_a + q_b + q_c = 0$$



Using superposition, the voltage V_{ab} for the first, second and third sections of the transposition are given respectively as

$$V_{ab}(1) = \frac{1}{2\pi\epsilon_0} \left(q_a \ln \frac{D_{ab}}{r} + q_b \ln \frac{r}{D_{ab}} + q_c \ln \frac{D_{bc}}{D_{ca}} \right) \quad V_{ab}(2) = \frac{1}{2\pi\epsilon_0} \left(q_a \ln \frac{D_{bc}}{r} + q_b \ln \frac{r}{D_{bc}} + q_c \ln \frac{D_{ca}}{D_{ab}} \right)$$

V

$$V_{ab}(3) = \frac{1}{2\pi\epsilon_0} \left(q_a \ln \frac{D_{ca}}{r} + q_b \ln \frac{r}{D_{ca}} + q_c \ln \frac{D_{ab}}{D_{bc}} \right)$$

$$V_{ab} = \frac{1}{2\pi\epsilon_0} \left(q_a \ln \frac{D_{ab}D_{bc}D_{ca}}{r^3} + q_b \ln \frac{r^3}{D_{ab}D_{bc}D_{ca}} + q_c \ln \frac{D_{ab}D_{bc}D_{ca}}{D_{ab}D_{bc}D_{ca}} \right) \quad V$$

Then the average value of the voltage is

$$V_{ab} = \frac{1}{2\pi \epsilon_0} \left(q_a \ln \frac{\sqrt[3]{D_{ab}D_{bc}D_{ca}}}{r} + q_b \ln \frac{r}{\sqrt[3]{D_{ab}D_{bc}D_{ca}}} \right) \text{ V}$$

This implies

$$V_{ab} = \frac{1}{2\pi \epsilon_0} \left(q_a \ln \frac{GMD}{r} + q_b \ln \frac{r}{GMD} \right) \text{ V}$$

The GMD of the conductors is given in (1.42). We can therefore write

$$V_{ac} = \frac{1}{2\pi \epsilon_0} \left(q_a \ln \frac{GMD}{r} + q_c \ln \frac{r}{GMD} \right)$$

Similarly the voltage V_{ac} is given as

$$\begin{aligned} V_{ab} + V_{ac} &= \frac{1}{2\pi \epsilon_0} \left[2q_a \ln \frac{GMD}{r} + (q_b + q_c) \ln \frac{r}{GMD} \right] \\ &= \frac{1}{2\pi \epsilon_0} \left[2q_a \ln \frac{GMD}{r} - q_a \ln \frac{r}{GMD} \right] = \frac{3}{2\pi \epsilon_0} q_a \ln \frac{GMD}{r} \end{aligned}$$

Adding (1.74) and (1.75) and using (1.68) we get

$$\begin{aligned} V_{ab} &= V_{an} \angle 0^\circ - V_{an} \angle -120^\circ \\ V_{ac} &= V_{an} \angle 0^\circ - V_{an} \angle -240^\circ \end{aligned}$$

For a set of balanced three-phase voltages

$$V_{ab} + V_{ac} = 2V_{an} \angle 0^\circ - V_{an} \angle -120^\circ - V_{an} \angle -240^\circ = 2V_{an} \angle 0^\circ \text{ V}$$

Therefore we can write

$$V_{an} = \frac{1}{2\pi \epsilon_0} q_a \ln \frac{GMD}{r}$$

Combining (1.76) and (1.77) we get

$$C = \frac{q_a}{V_{an}} = \frac{2\pi \epsilon_0}{\ln(GMD/r)} \text{ F/m}$$

Therefore the capacitance to neutral is given by

$$C = \frac{2\pi \epsilon_0}{\ln(GMD/r)}$$

For bundles conductor

where

$$\begin{aligned} D_b &= \sqrt{\pi d} \text{ for 2 bundle} \\ &= \sqrt[3]{\pi d^2} \text{ for 3 bundle} \\ &= 1.094 \sqrt[4]{\pi d^3} \text{ for 4 bundle conductors} \end{aligned}$$


EFFECT OF EARTH ON THE CALCULATION OF CAPACITANCE:

Earth affects the calculation of capacitance of three-phase lines as its presence alters the electric field lines. Usually the height of the conductors placed on transmission towers is much larger than the spacing between the conductors. Therefore the effect of earth can be neglected for capacitance calculations, especially when balanced steady state operation of the power system is considered. However for unbalanced operation when the sum of the three line currents is not zero, the effect of earth needs to be considered.

The capacitance of transmission line is affected by the presence of earth. Because of earth, electric field of a line is reduced. If we assume that the earth is a perfect conductor in the form of a horizontal plane of infinite extent, we realize that the electric field of charged conductors above the earth is not the same as it would be if the equipotential surface of earth were not present.

The method of images is used while considering this type of problems. For this consider a single phase line having 2 conductors as shown in the Fig. 1.

A fictitious conductor is placed below each conductor of the same size and shape as the overhead conductor lying directly below the original conductor at a distance equal to twice the distance of the conductor above the plane of ground. If the earth is removed and a charge equal and opposite to that of an overhead conductor is assumed on the fictitious conductor, the plane midway between conductor and its image is an equipotential surface and occupies the same position as the equipotential surface of earth. This fictitious conductor is called image conductor having the charge opposite to that of overhead conductor.



The voltage V_{ab} is given as,

$$V_{ab} = \frac{1}{2\pi\epsilon} \left\{ q_a \ln \frac{D}{r} + q_b \ln \frac{r}{D} \right\} + \frac{1}{2\pi\epsilon} \left\{ -q_a \ln \frac{\sqrt{D^2 + 4h^2}}{2h} - q_b \ln \frac{2h}{\sqrt{D^2 + 4h^2}} \right\}$$

$$= \frac{1}{2\pi\epsilon} \left\{ q_a \ln \frac{2hD}{r\sqrt{D^2 + 4h^2}} + q_b \ln \frac{r\sqrt{D^2 + 4h^2}}{2hD} \right\}$$

But $q_b = -q_a$

$$= \frac{1}{2\pi\epsilon} \left\{ q_a \ln \frac{2hD}{r\sqrt{D^2 + 4h^2}} - q_a \ln \frac{r\sqrt{D^2 + 4h^2}}{2hD} \right\}$$

$$= \frac{1}{2\pi\epsilon} q_a \ln \left[\frac{4h^2 D^2}{r^2 (D^2 + 4h^2)} \right] = \frac{1}{2\pi\epsilon} q_a \ln \left[\frac{D^2}{r^2 \left(1 + \frac{D^2}{4h^2} \right)} \right]$$

$$= \frac{1}{2\pi\epsilon} 2q_a \ln \left[\frac{D}{r \sqrt{r^2 \left(1 + \frac{D^2}{4h^2} \right)}} \right] = \frac{1}{\pi\epsilon} q_a \ln \left[\frac{D}{r \sqrt{1 + \frac{D^2}{4h^2}}} \right]$$

$$C_{ab} = \frac{q_a}{V_{ab}} = \frac{\pi\epsilon}{\ln \left[\frac{D}{r \sqrt{1 + \frac{D^2}{4h^2}}} \right]}$$

Comparing above equation with expression for capacitance of single phase line without considering the effect of earth, we can see that earth tries to increase the capacitance of line by small amount. But the effect is negligible if the conductors are high above ground compared to distances between them.

4.CORONA:

When an alternating potential difference is applied across two conductors whose spacing is large as compared to their diameters, there is no apparent change in the condition of atmospheric air surrounding the wires if the applied voltage is low.


However, when the applied voltage exceeds a certain value, called critical disruptive voltage, the conductors are surrounded by a faint violet glow called corona.

The phenomenon of corona is accompanied by a hissing sound, production of ozone, power loss and radio interference.

The higher the voltage is raised, the larger and higher the luminous envelope becomes, and greater are the sound, the power loss and the radio noise. If the applied voltage is increased to breakdown value, a flash-over will occur between the conductors due to the breakdown of air insulation.

Corona effect or corona discharge in transmission lines and power system may be defined as: The phenomenon of violet glow, hissing noise and production of ozone gas in an overhead transmission line is known as corona.

If the conductors are polished and smooth, the corona glow will be uniform throughout the length of the conductors, otherwise the rough points will appear brighter. With d.c. voltage, there is difference in the appearance of the two wires. The positive wire has uniform glow about it, while the negative conductor has spotty glow.



Theory of Corona Formation

Some ionization is always present in air due to cosmic rays, ultra-violet radiations and radioactivity. Therefore, under normal conditions, the air around the conductors contains some ionized particles (i.e., free electrons and +ve ions) and neutral molecules.

When p.d. is applied between the conductors, potential gradient is set up in the air which will have maximum value at the conductor surfaces. Under the influence of potential gradient, the existing free electrons acquire greater velocities. The greater the applied voltage, the greater the potential gradient and more is the velocity of free electrons.

When the potential gradient at the conductor surface reaches about 30 kV per cm (max. value), the velocity acquired by the free electrons is sufficient to strike a neutral molecule with enough force to dislodge one or more electrons from it.

This produces another ion and one or more free electrons, which in turn are accelerated until they collide with other neutral molecules, thus producing other ions. Thus, the process of ionization is cumulative. The result of this ionization is that either corona is formed or spark takes place between the conductors.

Mathematical Modelling of Corona Effect

Corona effect or corona discharge is a phenomenon that results from a partial discharge in the air (or in any fluid) caused by the ionization of the environment when an electrical current flows in a conductor and when the electric field gradient^[1] is strong enough to ionize the environment, but it is not strong enough to cause dielectric breakdown^[2] or arcing between the conductors.

This phenomenon that is characterized by a glow (mostly with a color in blue/violet spectrum), mainly happens in overhead lines, close to the suspension and strain insulators, when the distance between conductors is much greater than the diameters of the conductors.

Generally for parallel conductors in the air there is corona effect when.

$$D/r < 5.85$$

Where:

r is the radius of the conductors

D is the distance between the conductors

When studying corona effect it is important to evaluate the minimum value of the voltage between phases or between one phase and the neutral (or the ground) for which the corona effect takes place.

This voltage is named Critical Disruptive Voltage. If r [cm] is the radius of the conductor, d [cm] is the distance between the conductor and the neutral (or the ground) and U [V] is the gradient of the electric field E (mathematical notation: grad E), the critical disruptive voltage that we will designate as G , is calculated by the equation:

$$G = (U / (r \times \ln (d/r))) \text{ [V/m]}$$

Where \ln represents the natural logarithm.

To corona effect takes place it is necessary that G will be equal or greater than the disruption voltage of the air, that at atmospheric pressure ($1.01325 \times 10^5 \text{ Pa} = 1 \text{ atm} = 760 \text{ mmHg}^{[3]}$) and at a temperature of 25°C is equal to 30 kV/cm – considering the maximum value of U – or 21.2 kV/cm – considering the rms^[4] value of U .

Designating by G_0 the value of grad E that obeys to the above condition the critical value of the disruption voltage (U_c) is calculated by the equation:

$$U_c = G_0 \times r \times \ln (d/r) \text{ [kV/phase]}$$

For different conditions of temperature and of atmospheric pressure, the density of the air is also different; it is possible to express that variation by a factor δ that for a given pressure P [Pa] and temperature θ [$^\circ \text{C}$] is calculated by the equation:

$$\delta = (3.92 \times 1.01325 \times 10^5 \times P) / ((273 + \theta) \times 760)$$

Being G'_0 the value of grad E corresponding to the new atmospheric conditions, its value is calculated by the equation:

$$G'_0 = \delta \times G_0$$

Hence, the critical value of the disruption voltage (U'_c) is calculated by the equation:

$$U'_c = G_0 \times r \times \delta \times \ln (d/r) \text{ [kV/phase]}$$

Taking into account the irregularity of the conductor surface and expressing that irregularity as a factor m_0 , the value of U'_c is then:

$$U'_c = m_0 \times G_0 \times r \times \delta \times \ln (d/r) \text{ [kV/phase]}$$

Common values of m_0 are:

Polished conductors: $m_0 = 1$

Dirty conductors: $m_0 = 0.92-0.98$

Stranded conductors: $m_0 = 0.8-0.87$

Another value used to characterize the corona effect is the Visual Critical Voltage, represented by U_v , that is the minimum voltage between one phase and the neutral (or the ground) for which the corona effect takes place all along the conductor. That voltage is calculated by the following empirical equation:

$$U_v = m_v \times G_0 \times \delta \times 3 \times (1 + (0.3 / \sqrt{(\delta \times r)})) \times \ln (d/r) \text{ [kV/phase]}$$

Factor m_v is also a measure of the irregularity of the conductor, assuming the following values.

Polished conductors: $m_v = 1$

Rough conductors: $m_v = 0.72-0.82$

Another value that must be calculated when studying the corona effect is the losses caused by this effect; considering the rms value of U_c and being U the rms rated voltage of the network, both in kV, and f [Hz] the rated network frequency, losses by corona effect (P_{co}) are calculated by the equation:

$$P_{co} = 242.2 \times ((f + 25) / \delta) \times \sqrt{r/d} \times (U^2 - U_c^2) \times 10^{-5} [\text{kW/km/phase}]$$

Short Circuit Currents And Symmetrical Components

Important terms related to Corona

The phenomenon of corona plays an important role in the design of an overhead transmission line. Therefore, it is profitable to consider the following terms much used in the analysis of corona effects:

(i) Critical disruptive voltage

It is the minimum phase-neutral voltage at which corona occurs. Consider two conductors of radius r (cm) and spaced d (cm) apart. If V is the phase-neutral potential, then potential gradient at the conductor surface is given by:

$$g = [V / r \log_e (d/r)] \text{ volts / cm}$$

In order that corona is formed, the value of g must be made equal to the breakdown strength of air. The breakdown strength of air at 76 cm pressure and temperature of 25°C is 30 kV/cm (max) or 21.2 kV/cm (r.m.s.) and is denoted by g_0 .

If V_c is the phase-neutral potential required under these conditions, then,

$$g_0 = [V_c / r \log_e (d/r)] \text{ volts / cm}$$

where g_0 = breakdown strength of air at 76 cm of mercury and 25°C = 30 kV/cm (max) or 21.2 kV/cm (r.m.s.)

$$\therefore \text{Critical disruptive voltage, } V_c = g_0 r \log_e d/r$$

The above expression for disruptive voltage is under standard conditions i.e., at 76 cm of H_g and 25°C.

However, if these conditions vary, the air density also changes, thus altering the value of g_0 .

The value of g_0 is directly proportional to air density. Thus the breakdown strength of air at a barometric pressure of b (cm) of mercury and temperature of $t^\circ\text{C}$ becomes δg_0 where

$$\delta = \text{air density factor} = 3.92b / 273 + t$$

Under standard conditions, the value of $\delta = 1$.

$$\therefore \text{Critical disruptive voltage, } V_c = g_0 \delta r \log_e d/r$$

Correction must also be made for the surface condition of the conductor. This is accounted for by multiplying the above expression by irregularity factor m_0 .

$$\therefore \text{Critical disruptive voltage, } V_c = m_0 g_0 \delta r \log_e d/r \dots \text{ kV/phase}$$

where,

$$m_0 = 1 \text{ for polished conductors}$$

$$= 0.98 \text{ to } 0.92 \text{ for dirty conductors}$$

$$= 0.87 \text{ to } 0.8 \text{ for stranded conductors}$$

(ii) Visual critical voltage

It is the minimum phase-neutral voltage at which corona glow appears all along the line conductors.

It has been seen that in case of parallel conductors, the corona glow does not begin at the disruptive voltage V_c but at a higher voltage V_v , called visual critical voltage.

The phase-neutral effective value of visual critical voltage is given by the following empirical formula :

$$V_v = m_v g_o \delta r \left(1 + \frac{0.3}{\sqrt{\delta r}} \right) \log_e \frac{d}{r} \text{ kV/phase}$$

where m_v is another irregularity factor having a value of 1.0 for polished conductors and 0.72 to 0.82 for rough conductors.

Typical AC Power Supply system (Generation, Transmission and Distribution)

FACTORS & CONDITION EFFECTING CORONA:

The phenomenon of corona is affected by the physical state of the atmosphere as well as by the conditions of the line. The following are the factors upon which corona depends :

(i) Atmosphere

As corona is formed due to ionization of air surrounding the conductors, there-fore, it is affected by the physical state of atmosphere. In the stormy weather, the number of ions is more than normal and as such corona occurs at much less voltage as compared with fair weather.

(ii) Conductorsize

The corona effect depends upon the shape and conditions of the conductors. The rough and irregular surface will give rise to more corona because unevenness of the surface decreases the value of breakdown voltage. Thus a stranded conductor has irregular surface and hence gives rise to more corona than a solid conductor.

(iii) Spacing between conductors

If the spacing between the conductors is made very large as compared to their diameters, there may not be any corona effect. It is because larger distance between conductors reduces the electrostatic stresses at the conductor surface, thus avoiding corona formation.

(iv) Linevoltage

The line voltage greatly affects corona. If it is low, there is no change in the condition of air surrounding the conductors and hence no corona is formed. However, if the line voltage has such a value that electrostatic stresses developed at the conductor surface make the air around the conductor conducting, then corona is formed.

POWER LOSS DUE TO CORONA:

Formation of corona is always accompanied by energy loss which is dissipated in the form of light, heat, sound and chemical action. When disruptive voltage is exceeded, the power loss due to corona is given by:

$$P = 242 \cdot 2 \left(\frac{f + 25}{\delta} \right) \sqrt{\frac{r}{d}} (V - V_c)^2 \times 10^{-5} \text{ kW / km / phase}$$

where

f = supply frequency in Hz

V = phase-neutral voltage (r.m.s.)

V_c = disruptive voltage (r.m.s.) per phase

METHODS OF REDUCING CORONA EFFECT:

It has been seen that intense corona effects are observed at a working voltage of 33 kV or above. Therefore, careful design should be made to avoid corona on the sub-stations or bus-bars rated for 33kV and higher voltages otherwise highly ionized air may cause flash-over in the insulators or between the phases, causing considerable damage to the equipment.

The corona effects can be reduced by the following methods:

(i) By increasing conductor size

By increasing conductor size, the voltage at which corona occurs is raised and hence corona effects are considerably reduced. This is one of the reasons that ACSR conductors which have a larger cross-sectional area are used in transmission lines.

(ii) By increasing conductor spacing.

By increasing the spacing between conductors, the voltage at which corona occurs is raised and hence corona effects can be eliminated. However, spacing cannot be increased too much otherwise the cost of supporting structure (e.g., bigger cross arms and supports) may increase to a considerable extent.

EXAMPLES OF CORONA CALCULATION:

Example : A 3-phase line has conductors 2 cm in diameter spaced equilaterally 1 m apart.

If the dielectric strength of air is 30 kV (max) per cm, find the disruptive critical voltage for the line. Take air density factor $\alpha = 0.952$ and irregularity factor $m_0 = 0.9$.

Solution.

Conductor radius, $r = 2/2 = 1$ cm Conductor spacing, $d = 1$ m = 100 cm

Dielectric strength of air, $g_0 = 30$ kV/cm (max.) = 21.2

kV(r.m.s.) per cm Disruptive critical voltage, $V_c = m_0$

$g_0 \alpha r \log_e (d/r)$ kV*/phase (r.m.s. value)

$$= 0.9 \times 21.2 \times 0.952 \times 1 \times \log_e 100/1 = 83.64 \text{ kV/phase}$$

$$\text{Line voltage(r.m.s.)} = \sqrt{3} \times 83.64 = 144.8 \text{ kV}$$

ADVANTAGES AND DISADVANTAGES OF CORONA:

Corona effects on communication lines. Corona has many advantages and disadvantages. In the correct design of a high voltage overhead line, a balance should be struck between the advantages and disadvantages. Below are the Advantages and disadvantages of Corona.

Advantages:

1. Due to corona formation, the air surrounding the conductor becomes conducting and hence virtual diameter of the conductor is increased. The increased diameter reduces the electrostatic stresses between the conductors.
2. Corona reduces the effects of transients produced by surges.

Disadvantages:

1. Corona is accompanied by a loss of energy. This affects the transmission efficiency of the line.
2. Ozone is produced by corona and may cause corrosion of the conductor due to chemical action.

3. The current drawn by the line due to corona is non-sinusoidal and hence non-sinusoidal Voltage drop occurs in the line. This may cause inductive interference with neighboring Communication lines.

METHODS FOR REDUCING CORONA POWERLOSS:

Corona discharge is always accompanied by power loss (which is dissipated in the form of sound, light, heat and chemical action). Though it accounts for a small percentage of total losses, power loss due to corona becomes significant in foul or wet weather conditions. Corona discharge can be reduced by the following methods:

- By increasing the conductor size: As explained above, larger the diameter of the conductor, lesser the coronadischarge.
- By increasing the distance between conductors: Larger the conductor spacing, lesser thecorona.
- Using bundled conductors: Using a bundled conductor increases the effective diameter of the conductor. This results in reduction of the coronadischarge.
- Using corona rings: The electric field is greater where the conductor curvature is sharp. Therefore, corona discharge occurs first at the sharp points, edges and corners. To mitigate this, corona rings are employed at the terminals of very high voltage equipments such as at the bushings of a very high voltage transformer (Corona discharge also occurs in high voltage equipment). A corona ring is electrically connected to the high voltage conductor, encircling the points where corona discharge may occur. This significantly reduces the potential gradient at the surface of the conductor, as the ring distributes the charge across a wider area due to its smooth roundshape.

5.AUDIBLENOISE:

During corona activity, transmission lines (primarily those rated at 345 kV and above) can generate a small amount of sound energy. This audible noise can increase during foul weather conditions. Water drops may collect on the surface of the conductors and increase corona activity so that a crackling or humming sound may be heard near a transmission line. Transmission line audible noise is measured in decibels using a special weighting scale, the —A1 scale, that responds to different sound characteristics similar to the response of the human ear. Audible noise levels on typical 230 kV lines are very low and are usually not noticeable. For example, the calculated rainy weather audible noise for a 230 kV transmission line at the right-of-way edge is about 25 dBA, which is less than ambient levels in a library and much less than background noise for wind and rain.

6.RADIO AND TELEVISIONINTERFERENCE:

Overhead transmission lines do not, as a general rule, interfere with radio or TV reception. There are two potential sources for interference: corona and gap discharges. As described above, corona discharges can sometimes generate unwanted electrical signals. Corona-generated electrical noise decreases with distance from a transmission line and also decreases with higher frequencies (when it is a problem, it is usually for AM radio and not the higher frequencies associated with TV signals). Corona interference to radio and television reception is usually not a design problem for transmission lines rated at 230 kV and lower. Calculated radio and TV interference levels in fair weather and in rain are extremely low at the edge of the right-of-way for a 230 kV transmission line. The resulting signal-to-noise ratio will easily meet the reception guidelines of the Federal Communications Commission. Gap discharges are different from corona.

Gap discharges can develop on power lines at any voltage. They can take place at tiny electrical separations (gaps) that can develop between mechanically connected metal parts. A small electric spark discharges across the gap and can create unwanted electrical noise. The severity of gap discharge interference depends on the strength and quality of the transmitted radio or TV signal, the quality of the radio or TV set and antenna system, and the distance between the receiver and power line. (The large

majority of interference complaints are found to be attributable to sources other than power lines: poor signal quality, poor antenna, door bells, and appliances such as heating pads, sewing machines, freezers, ignition systems, aquarium thermostats, fluorescent lights, etc.). Gap discharges can occur on broken or poorly fitting line hardware, such as insulators, clamps, or brackets. In addition, tiny electrical arcs can develop on the surface of dirty or contaminated insulators, but this interference source is less significant than gap discharge.

Hardware is designed to be problem-free, but corrosion, wind motion, gunshot damage, and insufficient maintenance contribute to gap formation. Generally, interference due to gap discharges is less frequent for high-voltage transmission lines than lower-voltage lines. The reasons that transmission lines have fewer problems include: predominate use of steel structures, fewer structures, greater mechanical load on hardware, and different design and maintenance standards. Gap discharge interference can be avoided or minimized by proper design of the transmission line hardware parts, use of electrical bonding where necessary, and by careful tightening of fastenings during construction. Individual sources of gap discharge noise can be readily located and corrected. Arcing on contaminated insulators can be prevented by increasing the insulation in high contamination areas and with periodic washing of insulator strings.

UNIT – II

MODELING AND PERFORMANCE OF TRANSMISSION LINES

BASIS OF CLASSIFICATION OF TRANSMISSION LINE:

Over head transmission lines are classified based on the manner in which the capacitance is considered:

1) Short Transmission Lines:

Transmission lines whose length less than 80kms and operating voltage less than 20kV comes under short transmission line. Due to the smaller distance and lower voltage levels capacitance (shunt) effect is extremely low and hence capacitance effect is neglected. The performance of the short transmission lines depend on the resistance and inductance value of the line.

Though the resistance and inductance are distributed over the length of the line it is assumed that resistance and inductance values are taken as lumped at one place. The effect of transformers and generators are taken in to account by considering equivalent impedance to the impedance of the line

2) Medium Transmission Line:

Transmission lines having length between 80kms and 200kms and line voltages between 20kV and 100kV falls in the second category. As the length of the line and voltage levels are moderate or not as low as small transmission lines, charging currents (transmission lines draw charging currents when the transmission line conductor and ground forms a capacitor with air in between as dielectric medium due to increase in the potential between the conductor and ground) comes in to picture in the case of medium transmission lines. Hence capacitance value is considered in the case of medium transmission line. Though the capacitance is distributed throughout the length of the line, capacitance value is assumed to be concentrated at one or more points

3) Long Transmission Line:

Transmission Lines having length above 200kms and line voltage above 100kV comes under Long Transmission Lines. In Long lines impedance (Resistance and inductance in series) and admittance (shunt capacitance and shunt conductance in parallel) values are distributed uniformly throughout the length of the line


Every transmission line will have three basic electrical parameters. The conductors of the line will have electrical resistance, inductance, and capacitance. As the transmission line is a set of conductors being run from one place to another supported by transmission towers, the parameters are distributed uniformly along the line.

The electrical power is transmitted over a transmission line with a speed of light that is 3×10^8 m/sec. Frequency of the power is 50 Hz. The wave length of the voltage and current of the power can be determined by the equation given below, $f\lambda = v$ where, f is power frequency, λ is wave length and v is the speed of light.

$$\text{Therefore, } \lambda = \frac{v}{f}$$

$$\Rightarrow \lambda = \frac{3 \times 10^8}{50} = 6 \times 10^6 \text{ mtr} = 6,000 \text{ mtr}$$

Hence, the wave length of the transmitting power is quite long compared to the generally used line length of transmission line.




Voltage distribution of 50 Hz supply

For this reason, the transmission line, with length less than 160 km, the parameters are assumed to be lumped and not distributed. Such lines are known as electrically short transmission line. This electrically short transmission lines are again categorized as short transmission line (length up to 60 km) and medium transmission line (length between 60 and 160 km). The capacitive parameter of short transmission line is ignored whereas in case of medium length line the, capacitance is assumed to be lumped at the middle of the line or half of the capacitance may be considered to be lumped at each ends of the transmission line. Lines with length more than 160 km, the parameters are considered to be distributed over the line. This is called long transmissionline.

ABCD PARAMETERS OF TRANSMISSIONLINE:

A major section of power system engineering deals in the transmission of electrical power from one particular place (eg. generating station) to another like substations or distribution units with maximum efficiency. So it's of substantial importance for power system engineers to be thorough with its mathematical modeling. Thus the entire transmission system can be simplified to a **two port network** for the sake of easier calculations. The circuit of a 2 port network is shown in the diagram below. As the name suggests, a 2 port network consists of an input port PQ and an output port RS. In any 4 terminal network, (i.e. linear, passive, bilateral network) the input voltage and input current can be expressed in terms of output voltage and output current. Each port has 2 terminals to connect itself to the external circuit. Thus it is essentially a 2 port or a 4 terminal circuit, having



*Supply end voltage = V_S
and Supply end current = I_S*

Given to the input port PQ.

*And there is the Receiving end voltage = V_R
and Receiving end current = I_R*

Given to the output port RS. As shown in the diagram below. Now the **ABCD parameters** or the transmission line parameters provide the link between the supply and receiving end voltages and currents, considering the circuit elements to be linear in nature.


Thus the relation between the sending and receiving end specifications are given using **ABCD parameters** by the equations below.

$$V_S = AV_R + BI_R \dots\dots\dots (1)$$

$$I_S = CV_R + DI_R \dots\dots\dots (2)$$

Now in order to determine the ABCD parameters of transmission line let us impose the required circuit conditions in different cases.

ABCD Parameters, When Receiving End is Open Circuited



The receiving end is open circuited meaning receiving end current $I_R = 0$. Applying this condition to equation (1) we get,

$$V_S = AV_R + B \cdot 0 \Rightarrow V_S = AV_R + 0$$

$$A = \left. \frac{V_S}{V_R} \right|_{I_R = 0}$$

Thus it implies that on applying open circuit condition to ABCD parameters, we get parameter A as the ratio of sending end voltage to the open circuit receiving end voltage. Since dimension wise A is a ratio of voltage to voltage, A is a dimensionless parameter. Applying the same open circuit condition i.e $I_R = 0$ to equation (2)


$$I_S = C V_R + D \cdot 0 \Rightarrow I_S = C V_R + 0$$

$$C = \left. \frac{I_S}{V_R} \right|_{I_R = 0}$$

Thus it implies that on applying open circuit condition to ABCD parameters of transmission line, we get parameter C as the ratio of sending end current to the open circuit receiving end voltage. Since dimension wise C is a ratio of current to voltage, its unit is mho. Thus C is the open circuit conductance and is given by

$$C = I_S / V_R \text{ mho.}$$

ABCD Parameters, When Receiving End is Short Circuited



Receiving end is short circuited meaning receiving end voltage $V_R = 0$. Applying this condition to equation (1) we get,

$$V_S = A \cdot 0 + B I_R \Rightarrow V_S = 0 + B I_R$$

$$B = \left. \frac{V_S}{I_R} \right|_{V_R = 0}$$

Thus it implies that on applying short circuit condition to ABCD parameters, we get parameter B as the ratio of sending end voltage to the short circuit receiving end current. Since dimension wise B is a ratio of voltage to current, its unit is Ω . Thus B is the short circuit resistance and is given by $B = V_S / I_R \Omega$. Applying the same short circuit condition i.e. $V_R = 0$ to equation (2) we get

$$I_S = C \cdot 0 + D I_R \Rightarrow I_S = 0 + D I_R$$

$$D = \left. \frac{I_S}{I_R} \right|_{V_R = 0}$$

Thus it implies that on applying short circuit condition to ABCD parameters, we get parameter D as the ratio of sending end current to the short circuit receiving end current. Since dimension wise D is a ratio of current to current, it's a dimensionless parameter. \therefore

The ABCD parameters of transmission line can be tabulated as:


Parameter	Specification	Unit
$A = V_S / V_R$	Voltage ratio	Unit less
$B = V_S / I_R$	Short circuit resistance	Ω
$C = I_S / V_R$	Open circuit conductance	mho
$D = I_S / I_R$	Current ratio	Unit less

SHORT TRANSMISSION LINE:

The transmission lines which have length less than 80 km are generally referred as short transmission lines.

For short length, the shunt capacitance of this type of line is neglected and other parameters like resistance and inductance of these short lines are lumped, hence the equivalent circuit is represented as given below,

Let's draw the vector diagram for this equivalent circuit, taking receiving end current I_r as reference. The sending end and receiving end voltages make angle with that reference receiving end current, of ϕ_s and ϕ_r , respectively.



As the shunt capacitance of the line is neglected, hence sending end current and receiving end current is same, i.e.

$$I_s = I_r.$$

Now if we observe the vector diagram carefully, we will get, V_s is approximately equal to

$$V_r + I_r R \cos \phi_r + I_r X \sin \phi_r$$

That means,

$$V_s \approx V_r + I_r R \cos \phi_r + I_r X \sin \phi_r$$

as it is assumed that $\phi_s \approx \phi_r$

As there is no capacitance, during no load condition the current through the line is considered as zero, hence at no load condition, receiving end voltage is the same as sending end voltage

As per definition of voltage regulation,

$$\begin{aligned} \% \text{ regulation} &= \frac{V_s - V_r}{V_r} \times 100 \% \\ &= \frac{I_r R \cos \phi_r + I_r X \sin \phi_r}{V_r} \times 100 \% \\ \text{per unit regulation} &= \frac{I_r R}{V_r} \cos \phi_r + \frac{I_r X}{V_r} \sin \phi_r = v_r \cos \phi_r + v_x \sin \phi_r \end{aligned}$$

Here, v_r and v_x are the per unit resistance and reactance of the short transmission line. Any electrical network generally has two input terminals and two output terminals. If we consider any complex electrical network in a black box, it will have two input terminals and output terminals. This network is called two-port network. Two port model of a network simplifies the network solving technique. Mathematically a two port network can be solved by 2 by 2 matrixes.

A transmission as it is also an electrical network; line can be represented as two port network. Hence two port network of transmission line can be represented as 2 by 2 matrixes. Here the concept of ABCD parameters comes. Voltage and currents of the network can be represented as ,

$$V_s = AV_r + BI_r \dots\dots\dots (1)$$

$$I_s = CV_r + DI_r \dots\dots\dots (2)$$

Where A, B, C and D are different constant of the network.

If we put $I_r = 0$ at equation (1), we get

Hence, A is the voltage impressed at the sending end per volt at the receiving end when receiving end is open. It is dimension less. If we put $V_r = 0$ at equation (1), we get

$$B = \left. \frac{V_s}{I_r} \right|_{V_r = 0}$$

That indicates it is impedance of the transmission line when the receiving terminals are short circuited. This parameter is referred as transfer impedance.

$$C = \left. \frac{I_s}{V_r} \right|_{I_r = 0}$$

C is the current in amperes into the sending end per volt on open circuited receiving end. It has the dimension of admittance.

$$D = \left. \frac{I_s}{I_r} \right|_{V_r = 0}$$

D is the current in amperes into the sending end per amp on short circuited receiving end. It is dimensionless.

Now from equivalent circuit, it is found that,

$$V_s = V_r + I_r Z \text{ and } I_s = I_r$$

Comparing these equations with equation 1 and 2 we get,

A = 1, B = Z, C = 0 and D = 1. As we know that the constant A, B, C and

D are related

for passive network as

$$AD - BC = 1.$$

Here, A = 1, B = Z, C = 0 and D = 1

$$\Rightarrow 1.1 - Z.0 = 1$$

So the values calculated are correct for short transmission line.

From above equation (1),

$$V_s = AV_r + BI_r$$

When $I_r = 0$ that means receiving end terminals is open circuited and then from the equation 1, we get receiving end voltage at no load

$$V_r' = \frac{V_s}{A}$$

and as per definition of voltage regulation,

$$\% \text{ voltage regulation} = \frac{V_s / A - V_r}{V_r} \times 100 \%$$

Efficiency of Short TransmissionLine:

The efficiency of short line as simple as efficiency equation of any other electrical equipment, that means

$$\% \text{ efficiency } (\mu) = \frac{\text{Power received at receiving end}}{\text{Power delivered at sending end}} \times 100 \%$$

$$\% \mu = \frac{\text{Power received at receiving end}}{\text{Power received at receiving end} + 3I_r^2 R} \times 100 \%$$

MEDIUM TRANSMISSIONLINE:


The transmission line having its effective length more than 80 km but less than 250 km, is generally referred to as a medium transmission line. Due to the line length being considerably high, admittance Y of the network does play a role in calculating the effective circuit parameters, unlike in the case of short transmission lines. For this reason the modelling of a medium length transmission line is done using lumped shunt admittance along with the lumped impedance in series to the circuit.

These lumped parameters of a medium length transmission line can be represented using two different models, namely.

1. Nominal Π representation.
2. Nominal T representation.

Let's now go into the detailed discussion of these above mentioned models. Nominal Π representation of a medium transmission line In case of a nominal Π representation, the lumped series impedance is placed at the middle of the circuit where as the shunt admittances are at the ends. As we can see from the diagram of the Π network below, the total lumped shunt admittance is divided into 2 equal halves, and each half with value $Y/2$ is placed at both the sending and the receiving end while the entire circuit impedance is between the two. The shape of the circuit so formed resembles that of a symbol Π , and for this reason it is known as the nominal Π representation of a medium transmission line. It is mainly used for determining the general circuit parameters and performing load flow analysis.

NOMINAL Π REPRESENTATION OF A MEDIUM TRANSMISSIONLINE:



In case of a nominal Π representation, the lumped series impedance is placed at the middle of the circuit where as the shunt admittances are at the ends. As we can see from the diagram of the Π network below, the total lumped shunt admittance is divided into 2 equal halves, and each half with value $Y/2$ is placed at both the sending and the receiving end while the entire circuit impedance is between the two. The shape of the circuit so formed resembles that of a symbol Π , and for this reason it is known as the nominal Π representation of a medium transmission line. It is mainly used for determining the general circuit parameters and performing load flow analysis.

As we can see here, V_S and V_R is the supply and receiving end voltages respectively, and I_S is the current flowing through the supply end. I_R is the current flowing through the receiving end of the circuit. I_1 and I_3 are the values of currents flowing through the admittances.

And I_2 is the current through the impedance Z .

Now applying KCL, at node P, we get. $I_S = I_1 + I_2$ —————(1)

Similarly applying KCL, to node

Q. $I_2 = I_3 + I_R$ —————(2)

Now substituting equation (2) to equation

$$\begin{aligned} I_S &= I_1 + I_3 + I_R \\ &= \frac{Y}{2} V_S + \frac{Y}{2} V_R + I_R \text{-----(3)} \end{aligned}$$

Now by applying KVL to the circuit,

$$\begin{aligned} V_S &= V_R + Z I_2 \\ &= V_R + Z \left(V_R \frac{Y}{2} + I_R \right) \\ &= \left(Z \frac{Y}{2} + 1 \right) V_R + Z I_R \text{-----(4)} \end{aligned}$$

Now substituting equation (4) to equation (3), we get.

$$\begin{aligned} I_S &= \frac{Y}{2} \left[\left(\frac{Y}{2} Z + 1 \right) V_R + Z I_R \right] + \frac{Y}{2} V_R + I_R \\ &= Y \left(\frac{Y}{4} Z + 1 \right) V_R + \left(\frac{Y}{2} Z + 1 \right) I_R \text{-----(5)} \end{aligned}$$

Comparing equation (4) and (5) with the standard ABCD parameter equations

$$V_S = A V_R + B I_R$$

$$I_S = C V_R + D I_R$$

We derive the parameters of a medium transmission line as:

$$A = \left(\frac{Y}{2} Z + 1 \right)$$


$$B = Z \, \Omega$$

$$C = Y \left(\frac{Y}{4} Z + 1 \right)$$

$$D = \left(\frac{Y}{2} Z + 1 \right)$$

NOMINAL T REPRESENTATION OF A MEDIUM TRANSMISSIONLINE:

In the **nominal T** model of a medium transmission line the lumped shunt admittance is placed in the middle, while the net series impedance is divided into two equal halves and placed on either side of the shunt admittance. The circuit so formed resembles the symbol of a capital **T**, and hence is known as the nominal T network of a medium length transmission line and is shown in the diagram below.



Nominal-T representation.

Here also V_S and V_R is the supply and receiving end voltages respectively, and I_S is the current flowing through the supply end. I_R is the current flowing through the receiving end of the circuit. Let M be a node at the midpoint of the circuit, and the drop at M , be given by V_M . Applying KVL to the above network we get

$$\frac{V_S - V_M}{Z/2} = Y V_M + \frac{V_M - V_R}{Z/2}$$

$$\text{Or } V_M = \frac{2(V_S + V_R)}{YZ + 4} \quad (6)$$

And the receiving end current

$$\text{Or } I_R = \frac{2(V_M - V_R)}{Z/2} \quad (7)$$

Now substituting V_M from equation (6) to (7) we get,

$$\text{Or } I_R = \frac{[(2V_S + V_R) / YZ + 4] - V_R}{Z/2}$$

Rearranging the above equation:

$$V_S = \left(\frac{Y}{2}Z + 1\right)V_R + Z\left(\frac{Y}{4}Z + 1\right)I_R \quad (8)$$

Now the sending end current is

$$I_S = Y V_M + I_R \quad (9)$$

Substituting the value of V_M to equation (9) we get,

$$\text{Or } I_S = Y V_R + \left(\frac{Y}{2}Z + 1\right)I_R \quad (10)$$

Again comparing Comparing equation (8) and (10) with the standard ABCD parameter Equations

$$V_S = A V_R + B I_R$$

$$I_S = C V_R + D I_R$$

The parameters of the **T** network of a medium transmission line are

$$A = \left(\frac{Y}{2}Z + 1\right)$$


$$B = Z\left(\frac{Y}{4}Z + 1\right) \Omega$$

$$C = Y \text{ mho}$$

$$D = \left(\frac{Y}{2}Z + 1\right)$$


PERFORMANCE OF LONG TRANSMISSION LINE:

A power transmission line with its effective length of around 250 Kms or above is referred to as a long transmission line. Calculations related to circuit parameters (ABCD parameters) of such a power transmission is not that simple, as was the case for a short or medium transmission line. The reason being that, the effective circuit length in this case is much higher than what it was for the former models (long and medium line) and, thus ruling out the approximations considered there like.



Long Transmission Line model

For accurate modeling of the transmission line we must not assume that the parameters are lumped but are distributed throughout line. The single-line diagram of a long transmission line is shown in Fig. 2.5. The length of the line is l . Let us consider a small strip Δx that is at a distance x from the receiving end. The voltage and current at the end of the strip are V and I respectively and the beginning of the strip are $V + \Delta V$ and $I + \Delta I$ respectively. The voltage drop across the strip is then ΔV . Since the length of the strip is Δx , the series impedance and shunt admittance are $z \Delta x$ and $y \Delta x$. It is to be noted here that the total impedance and admittance of the line are $Z = z \times l$ and $Y = y \times l$



From the circuit of Fig. we see that

Here a line of length $l > 250\text{km}$ is supplied with a sending end voltage and current of V_S and I_S respectively, where as the V_R and I_R are the values of voltage and current obtained from the receiving end. Lets us now consider an element of infinitely small length Δx at a distance x from the receiving end as shown in the figure where.

V = value of voltage just before entering the element Δx .

I = value of current just before entering the element Δx .

$V + \Delta V$ = voltage leaving the element Δx .

$I + \Delta I$ = current leaving the element Δx .

ΔV = voltage drop across element Δx .

$z\Delta x$ = series impedance of element

$\Delta xy\Delta x$ = shunt admittance of element

Δx

Where $Z = z l$ and $Y = y l$ are the values of total impedance and admittance of the long transmission line.

\therefore the voltage drop across the infinitely small element Δx is given by

$$\Delta V = I z \Delta x$$

$$\text{Or } I z = \Delta V / \Delta x$$

$$\text{Or } I z = dV / dx \text{ —————(1)}$$

Now to determine the current ΔI , we apply KCL to node A.

$$\Delta I = (V + \Delta V)y\Delta x = V y\Delta x + \Delta V y\Delta x$$

Since the term $\Delta V y\Delta x$ is the product of 2 infinitely small values, we can ignore it for the sake of easier calculation.

$$\therefore \text{ we can write } dI / dx = V y \text{ —————(2)}$$

Now deriving both sides of eq (1) w.r.t x,

$$d^2 V / dx^2 = z dI / dx$$

Now substituting $dI / dx = V y$ from equation (2)

$$d^2 V / dx^2 = zyV$$

$$\text{or } d^2 V / dx^2 - zyV = 0 \text{ —————(3)}$$

The solution of the above second order differential equation is given by.

$$V = A_1 e^{x\sqrt{yz}} + A_2 e^{-x\sqrt{yz}} \text{ —————(4)}$$

Derivating equation (4) w.r.to x.

$$dV/dx = \sqrt{(yz)} A_1 e^{x\sqrt{yz}} - \sqrt{(yz)} A_2 e^{-x\sqrt{yz}} \text{ —————}$$

(5) Now comparing equation (1) with equation (5)

$$I = \frac{dV}{dx} = \frac{z A_1 e^{x\sqrt{(yz)}}}{\sqrt{(z/y)}} - \frac{z A_2 e^{-x\sqrt{(yz)}}}{\sqrt{(z/y)}} \text{ —————(6)}$$

Now to go further let us define the characteristic impedance Z_c and propagation constant δ of a long transmission line as

$$Z_c = \sqrt{(z/y)} \Omega \quad \delta = \sqrt{(yz)}$$

Then the voltage and current equation can be expressed in terms of characteristic impedance and propagation constant as

$$V = A_1 e^{\delta x} + A_2 e^{-\delta x} \text{ —————(7)}$$

$$I = A_1 / Z_c e^{\delta x} + A_2 / Z_c e^{-\delta x} \text{ —————(8)}$$

Now at $x=0$, $V = V_R$ and $I = I_R$. Substituting these conditions to equation (7) and (8) respectively. $V_R = A_1 + A_2$ —(9)

$$I_R = A_1 / Z_c + A_2 / Z_c \text{ —————(10)}$$

Solving equation (9) and (10), We get values of A_1 and A_2 as,

$$A_1 = (V_R + Z_c I_R) / 2$$

$$\text{And } A_2 = (V_R - Z_c I_R)$$

Now applying another extreme condition at $x=l$, we have $V = V_S$ and $I = I_S$.

Now to determine V_S and I_S we substitute x by l and put the values of A_1 and A_2 in equation (7) and (8) we get

$$V_S = (V_R + Z_c I_R) e^{\delta l} / 2 + (V_R - Z_c I_R) e^{-\delta l} / 2 \text{ —————(11)}$$

$$IS = (VR/ZC + IR)e^{\delta l/2} - (VR/ZC - IR)e^{-\delta l/2} \text{---(12)}$$

By trigonometric and exponential operators we know $\sinh \delta l = (e^{\delta l} - e^{-\delta l})/2$ And $\cosh \delta l = (e^{\delta l} + e^{-\delta l})/2$

∴ equation(11) and (12) can be re-written as

$$VS = VR \cosh \delta l + ZC IR \sinh \delta l$$

$$IS = (VR \sinh \delta l)/ZC + IR \cosh \delta l$$

Thus comparing with the general circuit parameters equation, we get the ABCD parameters\ of a long transmission line as,

$$C = \sinh \delta l / ZC \quad A = \cosh \delta l \quad D = \cosh \delta l \quad B = ZC \sinh \delta l$$

SURGE IMPEDANCE:

The characteristic impedance or surge impedance (usually written Z_0) of a uniform transmission line is the ratio of the amplitudes of voltage and current of a single wave propagating along the line; that is, a wave travelling in one direction in the absence of reflections in the other direction. Characteristic impedance is determined by the geometry and materials of the transmission line and, for a uniform line, is not dependent on its length. The SI unit of characteristic impedance is the ohm. The characteristic impedance of a lossless transmission line is purely real, with no reactive component. Energy supplied by a source at one end of such a line is transmitted through the line without being dissipated in the line itself. A transmission line of finite length (lossless or lossy) that is terminated at one end with an impedance equal to the characteristic impedance appears to the source like an infinitely long transmission line and produces no reflections.

The surge impedance loading:

The surge impedance loading (SIL) of a line is the power load at which the net reactive power is zero. So, if your transmission line wants to "absorb" reactive power, the SIL is the amount of reactive power you would have to produce to balance it out to zero. You can calculate it by dividing the square of the line-to-line voltage by the line's characteristic impedance. Transmission lines can be considered as, a small inductance in series and a small capacitance to earth, - a very large number of this combinations, in series. Whatever voltage drop occurs due to inductance gets compensated by capacitance. If this compensation is exact, you have surge impedance loading and no voltage drop occurs for an infinite length or, a finite length terminated by impedance of this value (SIL load). (Loss-less line assumed!). Impedance of this line (Z_s) can be proved to be $\sqrt{L/C}$. If capacitive compensation is more than required, which may happen on an unloaded EHV line, then you have voltage rise at the other end, the ferranti effect. Although given in many books, it continues to remain an interesting discussion always. The capacitive reactive power associated with a transmission line increases directly as the square of the voltage and is proportional to line capacitance and length.

Capacitance has two effects:

1. Ferranti effect
2. rise in the voltage resulting from capacitive current of the line flowing through the source impedances at the terminations of the line. SIL is Surge Impedance Loading and is calculated as $(KV \times KV) / Z_s$ their units are megawatts.

Where Z_s is the surge impedance....be aware...one thing is the surge impedance and other very different is the surge impedance loading.

Velocity of Propagation:


Velocity of propagation is a measure of how fast a signal travels over time, or the speed of the transmitted signal as compared to the speed of light. In computer technology, the velocity of propagation of an electrical or electromagnetic signal is the speed of transmission through a physical medium such as a coaxial cable or optical fiber. There is also a direct relation between velocity of propagation and wavelength. Velocity of propagation is often stated either as a percentage of the speed of light or as time-to-distance.

FERRANTI EFFECT:

In general practice we know, that for all electrical systems current flows from the region of higher potential to the region of lower potential, to compensate for the potential difference that exists in the system. In all practical cases the sending end voltage is higher than the receiving end, so current flows from the source or the supply end to the load. But Sir S.Z. Ferranti, in the year 1890, came up with an astonishing theory about medium or long distance transmission lines suggesting that in case of light loading or no load operation of transmission system, the receiving end voltage often increases beyond the sending end voltage, leading to a phenomena known as Ferranti effect in power system.

Why Ferranti effect occurs in a transmission line?

A long transmission line can be considered to be composed of a considerably high amount of capacitance and inductance distributed across the entire length of the line. Ferranti Effect occurs when current drawn by the distributed capacitance of the line itself is greater than the current associated with the load at the receiving end of the line (during light or no load). This capacitor charging current leads to voltage drop across the line inductance of the transmission system which is in phase with the sending end voltages. This voltage drop keeps on increasing additively as we move towards the load end of the line and subsequently the receiving end voltage tends to get larger than applied voltage leading to the phenomena called Ferranti effect in power system. It is illustrated with the help of a phasor diagram below.



Ferranti effect in transmission lines.

Thus both the capacitance and inductance effect of transmission line are equally responsible for this particular phenomena to occur, and hence Ferranti effect is negligible in case of a short transmission lines as the inductance of such a line is practically considered to be nearing zero. In general for a 300 Km line operating at a frequency of 50

Hz, the no load receiving end voltage has been found to be 5% higher than the sending end voltage. Now for analysis of Ferranti effect let us consider the phasor diagram shown above.

Here V_r is considered to be the reference phasor, represented by OA.

$$\text{Thus } V_r = V_r (1 + j0)$$

$$\text{Capacitance current, } I_c = j\omega CV_r$$

Now sending end voltage $V_s = V_r + \text{resistive drop} + \text{reactive drop}$.

$$= V_r + I_c R + jI_c X$$

$$= V_r + I_c (R + jX)$$

$$= V_r + j\omega C V_r (R + j\omega L) \text{ [since } X = \omega L]$$

$$\text{Now } V_s = V_r - \omega^2 C L V_r + j \omega C R V_r$$

This is represented by the phasor OC.

Now in case of a long transmission line, it has been practically observed that the line resistance is negligibly small compared to the line reactance, hence we can assume the length of the phasor $I_c R = 0$, we can consider the rise in the voltage is only due to OA–

OC = reactive drop in the line.

Now if we consider c_0 and L_0 are the values of capacitance and inductance per km of the transmission line, where l is the length of the line. Thus capacitive reactance $X_c = 1/(\omega l c_0)$

Since, in case of a long transmission line the capacitance is distributed throughout its length, the average current flowing is,

$$I_c = 1/2 V_r / X_c = 1/2 V_r \omega l c_0$$

Now the inductive reactance of the line = $\omega L_0 l$

Thus the rise in voltage due to line inductance is given by,

$$I_c X = 1/2 V_r \omega l c_0 X \omega L_0 l$$

$$\text{Voltage rise} = 1/2 V_r \omega^2 l^2 c_0 L_0$$

From the above equation it is absolutely evident, that the rise in voltage at the receiving end is directly proportional to the square of the line length, and hence in case of a long transmission line it keeps increasing with length and even goes beyond the applied sending end voltage at times, leading to the phenomena called Ferranti effect in powersystem.

UNIT – III

OVERHEAD INSULATORS AND UNDERGROUND CABLES

ELECTRICAL INSULATORS:

Electrical Insulator must be used in electrical system to prevent unwanted flow of current to the earth from its supporting points. The insulator plays a vital role in electrical system. Electrical Insulator is a very high resistive path through which practically no current can flow. In transmission and distribution system, the overhead conductors are generally supported by supporting towers or poles. The towers and poles both are properly grounded. So there must be insulator between tower or pole body and current carrying conductors to prevent the flow of current from conductor to earth through the grounded supporting towers or poles.

Insulating Material

The main cause of failure of overhead line insulator, is flash over, occurs in between line and earth during abnormal over voltage in the system. During this flash over, the huge heat produced by arcing, causes puncture in insulator body. Viewing this phenomenon the materials used for electrical insulator, has to possess some specific properties.

Properties of Insulating Material

The materials generally used for insulating purpose is called insulating material. For successful utilization, this material should have some specific properties as listed below.

1. It must be mechanically strong enough to carry tension and weight of conductors.
2. It must have very high dielectric strength to withstand the voltage stresses in High Voltage system.
3. It must possess high Insulation Resistance to prevent leakage current to the earth.
4. The insulating material must be free from unwanted impurities.
5. It should not be porous.
6. There must not be any entrance on the surface of electrical insulator so that the moisture or gases can enter it.
7. There physical as well as electrical properties must be less affected by changing temperature.

There are mainly three types of insulator used as overhead insulator likewise


1. Pin Insulator
2. Suspension Insulator
3. Strain Insulator

In addition to that there are other two types of electrical insulator available mainly for low voltage application i.e. Stray Insulator and Shackle Insulator.

PIN INSULATOR:

Pin Insulator is earliest developed overhead insulator, but still popularly used in power network up to 33KV system. Pin type insulator can be one part, two parts or three parts type, depending upon application voltage. In 11KV system we generally use one part type insulator where whole pin insulator is one piece of properly shaped porcelain or glass. As the leakage path of insulator is through its surface, it is desirable to increase the vertical length of the insulator surface area for lengthening leakage path. In order to obtain lengthy leakage path, one, tower or more rain sheds or petticoats are provided on the insulator

body. In addition to that rain shed or petticoats on an insulator serve another purpose. These rain sheds or petticoats are so designed, that during raining the outer surface of the rain shed becomes wet but the inner surface remains dry and non-conductive. So there will be discontinuations of conducting path through the wet pin insulator surface.



Pin Insulator:

In higher voltage like 33KV and 66KV manufacturing of one part porcelain pin insulator becomes difficult. Because in higher voltage, the thickness of the insulator become more and a quite thick single piece porcelain insulator cannot manufactured practically. In this case we use multiple part pin insulator, where a number of properly designed porcelain shells are fixed together by Portland cement to form one complete insulator unit. For 33KV tow parts and for 66KV three parts pin insulator are generally used.

Designing Consideration of Electrical Insulator:

The live conductor attached to the top of the pin insulator is at a potential and bottom of the insulator fixed to supporting structure of earth potential. The insulator has to withstand the potential stresses between conductor and earth. The shortest distance between conductor and earth, surrounding the insulator body, along which electrical discharge may take place through air, is known as flash over distance.

1. When insulator is wet, its outer surface becomes almost conducting. Hence the flash over distance of insulator is decreased. The design of an electrical insulator should be such that the decrease of flash over distance is minimum when the insulator is wet. That is why the upper most petticoat of a pin insulator has umbrella type designed so that it can protect, the rest lower part of the insulator from rain. The upper surface of top most petticoat is inclined as less as possible to maintain maximum flash over voltage during raining.
2. To keep the inner side of the insulator dry, the rain sheds are made in order that these rain sheds should not disturb the voltage distribution they are so designed that their subsurface at right angle to the electromagnetic lines of force.

POSTINSULATOR:



Post insulator is more or less similar to Pin insulator, but former is suitable for higher voltage application. Post insulator has higher numbers of petticoats and has greater height. We can mount this type of insulator on supporting structure horizontally as well as vertically. The insulator is made of one piece of porcelain and it has clamp arrangement are in both top and bottom end for fixing. The main differences between pin insulator and post insulator are,

SL	Pin Insulator	Post Insulator
1	It is generally used up to 33KV system	It is suitable for lower voltage and also for higher voltage
2	It is single stag	It can be single stag as well as multiple stags
3	Conductor is fixed on the top of the insulator by binding	Conductor is fixed on the top of the insulator with help of connector clamp
4	Two insulators cannot be fixed together for higher voltage application	Two or more insulators can be fixed together one above other for higher voltage application
4	Metallic fixing arrangement provided only on bottom end of the insulator	Metallic fixing arrangement provided on both top and bottom ends of the insulator

SUSPENSION INSULATOR:

In higher voltage, beyond 33KV, it becomes uneconomical to use pin insulator because size, weight of the insulator become more. Handling and replacing bigger size single unit insulator are quite difficult task. For overcoming these difficulties, **suspension insulator** was developed. In **suspension insulator** numbers of insulators are connected in series to form a string and the line conductor is carried by the bottom most insulator. Each insulator of a suspension string is called disc insulator because of their disc like shape.

Advantages of Suspension Insulator:

- (i) Suspension type insulators are cheaper than pin type insulators for voltages beyond 33kV.
- (ii) Each unit or disc of suspension type insulator is designed for low voltage, usually 11 kV. Depending upon the working voltage, the desired number of discs can be connected in series.
- (iii) If anyone disc is damaged, the whole string does not become useless because the damaged disc can be replaced by the sound one.
- (iv) The suspension arrangement provides greater flexibility to the line. The connection at the cross arm is such that insulator string is free to swing in any direction and can take up the position where mechanical stresses are minimum.



- (v) In case of increased demand on the transmission line, it is found more satisfactory to supply the greater demand by raising the line voltage than to provide another set of conductors. The additional insulation required for the raised voltage can be easily obtained in the suspension arrangement by adding the desired number of discs.
- (vi) The suspension type insulators are generally used with steel towers. As the conductors run below the earthed cross-arm of the tower, therefore, this arrangement provides partial protection from lightning.

Disadvantages of Suspension Insulator:

- (1). Suspension insulator string costlier than pin and post type insulator.
- (2). Suspension string requires more height of supporting structure than that for pin or post insulator to maintain same ground clearance of current conductor.
- (3). The amplitude of free swing of conductors is larger in suspension insulator system, hence, more spacing between conductors should be provided.

STRAIN INSULATOR:


When suspension string is used to sustain extraordinary tensile load of conductor it is referred as strain insulator. When there is a dead end or there is a sharp corner in transmission line, the line has to sustain a great tensile load of conductor or strain. A strain insulator must have considerable mechanical strength as well as the necessary electrical insulating properties.




STRAIN INSULATOR

Rated System Voltage	Number of disc insulator used in strain type tension insulator string	Number of disc insulator used in suspension insulator string
33KV	3	3
66KV	5	4
132KV	9	8
220KV	15	14

STAY INSULATOR:



For low voltage lines, the stays are to be insulated from ground at a height. The insulator used in the stay wire is called as the **stay insulator** and is usually of porcelain and is so designed that in case of breakage of the insulator the guy-wire will not fall to the ground.



Shackle or Spool Insulator

SHACKLE INSULATOR OR SPOOLINSULATOR:

The **shackle insulator** or **spool insulator** is usually used in low voltage distribution network. It can be used both in horizontal and vertical position. The use of such insulator has decreased recently after increasing the using of underground cable for distribution purpose. The tapered hole of the **spool insulator** distributes the load more evenly and minimizes the possibility of breakage when heavily loaded. The conductor in the groove of **shackle insulator** is fixed with the help of soft binding wire.

POTENTIAL DISTRIBUTION OVER A STRING OF SUSPENSION INSULATORS:


A string of suspension insulators consists of a number of porcelain discs connected in series through metallic links. Fig. 2.3(i) shows 3-disc string of suspension insulators. The porcelain portion of each disc is in between two metal links. Therefore, each disc forms a capacitor C as shown in Fig.2.3(ii). This is known as mutual capacitance or self-capacitance.

If there were mutual capacitance alone, then charging current would have been the same through all the discs and consequently voltage across each unit would have been the same i.e., $V/3$ as shown in Fig. 2.3(ii). However, in actual practice, capacitance also exists between metal fitting of each disc and tower or earth. This is known as shunt capacitance C_1 . Due to shunt capacitance, charging current is not the same through all the discs of the string [See Fig2.3(iii)]. Therefore, voltage across each disc will be different.


Obviously, the disc nearest to the line conductor will have the maximum voltage. Thus referring to Fig 2.3(iii), V_3 will be much more than V_2 or V_1 .

The following points may be noted regarding the potential distribution over a string of suspension insulators:

- The voltage impressed on a string of suspension insulators does not distribute itself uniformly across the individual discs due to the presence of shunt capacitance.
- The disc nearest to the conductor has maximum voltage across it. As we move towards the cross-arm, the voltage across each disc goes on decreasing.
- The unit nearest to the conductor is under maximum electrical stress and is likely to be punctured. Therefore, means must be provided to equalize the potential across each unit.
- The presence of stray capacitance causes unequal potential distribution over the string. The end unit of the string (which is the closest to the line) takes maximum potential difference and the upper units have a gradually decreased potential difference until the uppermost unit which has the lowest potential difference. The next proof illustrates this concept.



Suspension Insulator string



(a) 3-disc string insulator

(b) equivalent circuit

If there were only mutual capacitances, then the charging current would have been the same through all the discs. In this case, the voltage would have been uniformly distributed across the string, i.e. voltage across

each disc would have been the same. But, due to the shunt capacitances, charging current is not the same through all the discs.

From the above equivalent circuit, applying Kirchoff's current law to node A,

$$I_2 = I_1 + i_1$$

$$V_2 \omega C = V_1 \omega C + V_1 \omega k C$$

$$V_2 = V_1 + V_1 k$$

$$V_2 = (1+k)V_1 \dots \dots \dots \text{eq.(i)}$$

applying Kirchoff's current law to node B,

$$I_3 = I_2 + i_2$$

$$V_3 \omega C = V_2 \omega C + (V_2 + V_1) \omega k C$$

$$V_3 = V_2 + (V_1 + V_2)k$$

$$V_3 = kV_1 + (1 + k) V_2$$

$$V_3 = kV_1 + (1 + k)^2 V_1 \dots \dots \dots \text{from eq.(i)}$$

$$V_3 = V_1 [k + (1 + k)^2]$$

$$V_3 = V_1 [k + 1 + 2k + k^2]$$

$$V_3 = V_1 (1 + 3k + k^2) \dots \dots \dots \text{eq.(ii)}$$

Now, voltage between the conductor and the earther tower is,

$$V = V_1 + V_2 + V_3$$

$$V = V_1 + (1 + k)V_1 + V_1 (1 + 3k + k^2)$$

$$V = V_1 (3 + 4k + k^2) \dots \dots \dots \text{eq.(iii)}$$

from the above equations (i), (ii) & (iii), it is clear that the voltage across the top disc is minimum while voltage across the disc nearest to the conductor is maximum, i.e. $V_3 = V_1 (1 + 3k + k^2)$. As we move towards the cross arm, voltage across the disc goes on decreasing. Due to this non-uniform voltage distribution across the string, the unit nearest to the conductor is under maximum electrical stress and is likely to be punctured.

STRING EFFICIENCY:

As explained above, voltage is not uniformly distributed over a suspension insulator string. The disc nearest to the conductor has maximum voltage across it and, hence, it will be under maximum electrical stress. Due to this, the disc nearest to the conductor is likely to be punctured and subsequently, other discs may puncture successively. Therefore, this unequal voltage distribution is undesirable and usually expressed in terms of string efficiency. The ratio of voltage across the whole string to the product of number of discs and the voltage across the disc nearest to the conductor is called as **string efficiency**

String efficiency = Voltage across the string / (number of discs X voltage across the disc nearest to the conductor).

Greater the string efficiency, more uniform is the voltage distribution. String efficiency becomes 100% if the voltage across each disc is exactly the same, but this is an ideal case and impossible in practical scenario. However, for DC voltages, insulator capacitances are ineffective and voltage across each unit would be the same. This is why string efficiency for DC system is 100%.

Inequality in voltage distribution increases with the increase in the number of discs in a string. Therefore, shorter strings are more efficient than longer string insulators.

METHODS OF IMPROVING STRING EFFICIENCY:

Using Longer Cross Arms:

It is clear from the above mathematical expression of string efficiency that the value of string efficiency depends upon the value of k . Lesser the value of k , the greater is the string efficiency. As the value of k approaches to zero, the string efficiency approaches to 100%. The value of k can be decreased by reducing the shunt capacitance. In order to decrease the shunt capacitance, the distance between the insulator string and the tower should be increased, i.e. longer cross-arms should be used. However, there is a limit in increasing the length of cross-arms due to economic considerations.

Grading Of Insulator Discs:

In this method, voltage across each disc can be equalized by using discs with different capacitances. For equalizing the voltage distribution, the top unit of the string must have minimum capacitance, while the disc nearest to the conductor must have maximum capacitance. The insulator discs of different dimensions are so chosen that each disc has a different capacitance. They are arranged in such a way that the capacitance increases progressively towards the bottom. As voltage is inversely proportional to capacitance, this method tends to equalize the voltage distribution across each disc.

By Using A Guard Or Grading Ring:

A guard ring or grading ring is basically a metal ring which is electrically connected to the conductor surrounding the bottom unit of the string insulator. The guard ring introduces capacitance between metal links and the line conductor which tends to cancel out the shunt capacitances. As a result, nearly same charging current flows through each disc and, hence, improving the string efficiency. Grading rings are sometimes similar to corona rings, but they encircle insulators rather than conductors.

UNDERGROUND CABLES:

Electric power can be transmitted or distributed either by overhead system or by underground cables. The underground cables have several advantages such as less liable to damage through storms or lightning, low maintenance cost, less chances of faults, smaller voltage drop and better general appearance. However, their major drawback is that they have greater installation cost and introduce insulation problems at high voltages compared with the equivalent overhead system. For this reason, underground cables are employed where it is impracticable to use overhead lines. Such locations may be thickly populated areas where municipal authorities prohibit overhead lines for reasons of safety, or around plants and substations or where maintenance conditions do not permit the use of overhead construction.

The chief use of underground cables for many years has been for distribution of electric power in congested urban areas at comparatively low or moderate voltages. However, recent improvements in the design and manufacture have led to the development of cables suitable for use at high voltages. This has made it possible to employ underground cables for transmission of electric power for short or moderate distances. In this chapter, we shall focus our attention on the various aspects of underground cables and their increasing use in power system.

UNDERGROUND CABLES:

An underground cable essentially consists of one or more conductors covered with suitable insulation and surrounded by a protecting cover.

Although several types of cables are available, the type of cable to be used will depend upon the working voltage and service requirements. In general, a cable must fulfil the following necessary requirements :

1. The conductor used in cables should be tinned stranded copper or aluminium of high conductivity. Stranding is done so that the conductor may become flexible and carry more current.
2. The conductor size should be such that the cable carries the desired load current without overheating and causes voltage drop within permissible limits.
3. The cable must have proper thickness of insulation in order to give high degree of safety and reliability at the voltage for which it is designed.
4. The cable must be provided with suitable mechanical protection so that it may withstand the rough use in laying it.
5. The materials used in the manufacture of cables should be such that there is complete chemical and physical stability throughout.

CONSTRUCTION OF CABLES

Fig. 11.1 shows the general construction of a 3-conductor cable. The various parts are :

- (i) **Cores or Conductors.** A cable may have one or more than one core (conductor) depending upon the type of service for which it is intended. For instance, the 3-conductor cable shown in Fig. 11.1 is used for 3-phase service. The conductors are made of tinned copper or aluminium and are usually stranded in order to provide flexibility to the cable.
- (ii) **Insulation.** Each core or conductor is provided with a suitable thickness of insulation, the thickness of layer depending upon the voltage to be withstood by the cable. The commonly used materials for insulation are impregnated paper, varnished cambric or rubber mineral compound.




Fig. 11.1 Construction of a Cable

- (iii) **Metallic sheath.** In order to protect the cable from moisture, gases or other damaging liquids (acids or alkalis) in the soil and atmosphere, a metallic sheath of lead or aluminium is provided over the insulation as shown in Fig. 11.1
- (iv) **Bedding.** Over the metallic sheath is applied a layer of bedding which consists of a fibrous material like jute or hessian tape. The purpose of bedding is to protect the metallic sheath against corrosion and from mechanical injury due to armouring.
- (v) **Armouring.** Over the bedding, armouring is provided which consists of one or two layers of

galvanized steel wire or steel tape. Its purpose is to protect the cable from mechanical injury while laying it and during the course of handling. Armouring may not be done in the case of some cables.

- (vi) **Serving.** In order to protect armouring from atmospheric conditions, a layer of fibrous material (like jute) similar to bedding is provided over the armouring. This is known as serving.

It may not be out of place to mention here that bedding, armouring and serving are only applied to the cables for the protection of conductor insulation and to protect the metallic sheath from mechanical injury.

INSULATING MATERIALS FOR CABLES:

The satisfactory operation of a cable depends to a great extent upon the characteristics of insulation used. Therefore, the proper choice of insulating material for cables is of considerable importance. In general, the insulating materials used in cables should have the following properties:

1. High insulation resistance to avoid leakage current.
2. High dielectric strength to avoid electrical breakdown of the cable.
3. High mechanical strength to withstand the mechanical handling of cables.
4. Non-hygroscopic *i.e.*, it should not absorb moisture from air or soil. The moisture tends to decrease the insulation resistance and hastens the breakdown of the cable. In case the insulating material is hygroscopic, it must be enclosed in a waterproof covering like lead sheath.
5. Non-inflammable.
6. Low cost so as to make the underground system a viable proposition.
7. Unaffected by acids and alkalis to avoid any chemical action.

No one insulating material possesses all the above mentioned properties. Therefore, the type of insulating material to be used depends upon the purpose for which the cable is required and the quality of insulation to be aimed at. The principal insulating materials used in cables are rubber, vulcanized India rubber, impregnated paper, varnished cambric and polyvinyl chloride.

- i. **Rubber.** Rubber may be obtained from milky sap of tropical trees or it may be produced from oil products. It has relative permittivity varying between 2 and 3, dielectric strength is about 30 kV/mm and resistivity of insulation is 10^{17} cm. Although pure rubber has reasonably high insulating properties, it suffers from some major drawbacks *viz.*, readily absorbs moisture, maximum safe temperature is low (about 38°C), soft and liable to damage due to rough handling and ages when exposed to light. Therefore, pure rubber cannot be used as an insulating material.
- ii. **Vulcanized India Rubber (V.I.R.).** It is prepared by mixing pure rubber with mineral matters such as zinc oxide, red lead etc., and 3 to 5% of sulphur. The compound so formed is rolled into thin sheets and cut into strips. The rubber compound is then applied to the conductor and is heated to a temperature of about 150°C. The whole process is called vulcanization and the product obtained is known as vulcanized India rubber.

Vulcanized India rubber has greater mechanical strength, durability and wear resistant property than pure rubber. Its main drawback is that sulphur reacts very quickly with copper and for this reason, cables using VIR insulation have tinned copper conductor. The VIR insulation is generally used for low and moderate voltage cables.

- iii. **Impregnated paper.** It consists of chemically pulped paper made from wood chippings and impregnated with some compound such as paraffinic or naphthenic material. This type of insulation has almost superseded the rubber insulation. It is because it has the advantages of low cost, low capacitance, high dielectric strength and high insulation resistance. The only disadvantage is that paper is hygroscopic and even if it is impregnated with suitable compound, it absorbs moisture and thus lowers the insulation resistance of the cable. For this reason, paper insulated cables are always provided with some protective covering and are never left unsealed. If it is required to be left unused on the site during laying, it is temporarily covered with wax or tar.

Since the paper insulated cables have the tendency to absorb moisture, they are used where the cable route has a few joints. For instance, they can be profitably used for distribution at low voltages in congested areas where the joints are generally provided only at the terminal apparatus. However, for smaller installations, where the lengths are small and joints are required at a number of places, VIR cables will be cheaper and durable than paper insulated cables.

- iv. **Varnished cambric.** It is a cotton cloth impregnated and coated with varnish. This type of insulation is also known as *empire tape*. The cambric is lapped on to the conductor in the form of a tape and its surfaces are coated with petroleum jelly compound to allow for the sliding of one turn over another as the cable is bent. As the varnished cambric is hygroscopic, therefore, such cables are always provided with metallic sheath. Its dielectric strength is about 4 kV/mm and permittivity is 2.5 to 3.8.
- v. **Polyvinyl chloride (PVC).** This insulating material is a synthetic compound. It is obtained from the polymerization of acetylene and is in the form of white powder. For obtaining this material as a cable insulation, it is compounded with certain materials known as plasticizers which are liquids with high boiling point. The plasticizer forms a gel and renders the material plastic over the desired range of temperature.

Polyvinyl chloride has high insulation resistance, good dielectric strength and mechanical toughness over a wide range of temperatures. It is inert to oxygen and almost inert to many alkalis and acids. Therefore, this type of insulation is preferred over VIR in extreme environmental conditions such as in cement factory or chemical factory. As the mechanical properties (i.e., elasticity etc.) of PVC are not so good as those of rubber, therefore, PVC insulated cables are generally used for low and medium domestic lights and power installations.

CLASSIFICATION OF CABLES:

Cables for underground service may be classified in two ways according to (i) the type of insulating material used in their manufacture (ii) the voltage for which they are manufactured. However, the latter method of classification is generally preferred, according to which cables can be divided into the following groups:


- i. Low-tension (L.T.) cables — up to 1000V
- ii. High-tension (H.T.) cables — up to 11,000V
- iii. Super-tension (S.T.) cables — from 22 kV to 33kV
- iv. Extra high-tension (E.H.T.) cables — from 33 kV to 66kV
- v. Extra super voltage cables — beyond 132kV

A cable may have one or more than one core depending upon the type of service for which it is intended. It may be (i) single-core (ii) two-core (iii) three-core (iv) four-core etc. For a 3-phase service, either

3-single-core cables or three-core cable can be used depending upon the operating voltage and load demand.

Fig. 11.2 shows the constructional details of a single-core low tension cable. The cable has ordinary construction because the stresses developed in the cable for low voltages (upto 6600V) are generally small.


It consists of one circular core of tinned stranded copper (or aluminium) insulated by layers of impregnated paper. The insulation is surrounded by a lead sheath which prevents the entry of moisture into the inner parts. In order to protect the lead sheath from corrosion, an overall serving of compounded fibrous material (jute etc.) is provided. Single-core cables are not usually armoured in order to avoid excessive sheath losses. The principal advantages of single-core cables are simple construction and availability of larger copper section.



CABLES FOR 3-PHASE SERVICE:

In practice, underground cables are generally required to deliver 3-phase power. For the purpose, either three-core cable or *three single core cables may be used. For voltages up to 66 kV, 3-core cable (*i.e.*, multi-core construction) is preferred due to economic reasons. However, for voltages beyond 66 kV, 3-core cables become too large and unwieldy and, therefore, single-core cables are used. The following types of cables are generally used for 3-phase service:

1. Belted cables — up to 11kV
2. Screened cables — from 22 kV to 66kV
3. Pressure cables — beyond 66kV.



1. **Belted cables.** These cables are used for voltages upto 11kV but in extraordinary cases, their use may be extended upto 22kV. Fig. 11.3 shows the constructional details of a 3-core belted cable. The cores are insulated from each other by layers of impregnated paper. Another layer of impregnated paper tape, called *paper belt* is wound round the grouped insulated cores. The gap between the insulated cores is filled with fibrous insulating material (jute etc.) so as to give circular cross-section to the cable. The cores are generally stranded and may be of non-circular shape to make better use of

available space. The belt is covered with lead sheath to protect the cable against ingress of moisture and mechanical injury. The lead sheath is covered with one or more layers of armouring with an outer serving (not shown in the figure).


The belted type construction is suitable only for low and medium voltages as the electrostatic stresses developed in the cables for these voltages are more or less radial *i.e.*, across the insulation. However, for high voltages (beyond 22 kV), the tangential stresses also become important. These stresses act along the layers of paper insulation. As the insulation resistance of paper is quite small along the layers, therefore, tangential stresses set up leakage current along the layers of paper insulation. The leakage current causes local heating, resulting in the risk of breakdown of insulation at any moment. In order to overcome this difficulty, *screened cables* are used where leakage currents are conducted to earth through metallic screens.

2. **Screened cables.** These cables are meant for use up to 33 kV, but in particular cases their use may be extended to operating voltages up to 66 kV. Two principal types of screened cables are H-type cables and S.L. type cables.

- i. **H-type cables:-** This type of cable was first designed by H. Hochstadter and hence the name. Fig. 11.4 shows the constructional details of a typical 3-core, H-type cable. Each core is insulated by layers of impregnated paper. The insulation on each core is covered with a metallic screen which usually consists of a perforated aluminium foil. The cores are laid in such a way that metallic screens make contact with one another. An additional conducting belt (copper woven fabric tape) is wrapped round the three cores. The cable has no insulating belt but lead sheath, bedding, armouring and serving follow as usual. It is easy to see that each core screen is in electrical contact with the conducting belt and the lead sheath. As all the four screens (3 core screens and one conducting belt) and the lead sheath are at earth potential, therefore, the electrical stresses are purely radial and consequently dielectric losses are reduced.

Two principal advantages are claimed for H-type cables. Firstly, the perforations in the metallic screens assist in the complete impregnation of the cable with the compound and thus the possibility of air pockets or voids (vacuous spaces) in the dielectric is eliminated. The voids if present tend to reduce the breakdown strength of the cable and may cause considerable damage to the paper insulation. Secondly, the metallic screens increase the heat dissipating power of the cable.

- ii. **S.L. type cables:** Fig. 11.5 shows the constructional details of a 3-core S.L. (separate lead) type cable. It is basically H-type cable but the screen round each core insulation is covered by its own lead sheath. There is no overall lead sheath but only armouring and serving are provided. The S.L. type cables have two main advantages over H-type cables. Firstly, the separate sheaths minimize the possibility of core-to-core breakdown. Secondly, bending of cables becomes easy due to the elimination of overall lead sheath. However, the disadvantage is that the three lead sheaths of S.L. cable are much thinner than the single sheath of H-cable and, therefore, call for greater care in manufacture.



Limitations of solid type cables:

All the cables of above construction are referred to as solid type cables because solid insulation is used and no gas or oil circulates in the cable sheath. The voltage limit for solid type cables is 66 kV due to the following reasons:


- a) As a solid cable carries the load, its conductor temperature increases and the cable compound (i.e., insulating compound over paper) expands. This action stretches the lead sheath which may be damaged.
 - b) When the load on the cable decreases, the conductor cools and a partial vacuum is formed within the cable sheath. If the pinholes are present in the lead sheath, moisture may be drawn into the cable. The moisture reduces the dielectric strength of insulation and may eventually cause the break-down of the cable.
 - c) In practice, voids are always present in the insulation of a cable. Modern techniques of manufacturing have resulted in void-free cables. However, under operating conditions, the voids are formed as a result of the differential expansion and contraction of the sheath and impregnated compound. The breakdown strength of voids is considerably less than that of the insulation. If the void is small enough, the electrostatic stress across it may cause its breakdown. The voids nearest to the conductor are the first to break down, the chemical and thermal effects of ionization causing permanent damage to the paper insulation.
3. **Pressure cables** For voltages beyond 66 kV, solid type cables are unreliable because there is a danger of breakdown of insulation due to the presence of voids. When the operating voltages are greater than 66 kV, pressure cables are used. In such cables, voids are eliminated by increasing the pressure of compound and for this reason they are called pressure cables. Two types of pressure cables viz. oil-filled cables and gas pressure cables are commonly used.

Oil-filled cables. In such types of cables, channels or ducts are provided in the cable for oil circulation. The oil under pressure (it is the same oil used for impregnation) is kept constantly supplied to the channel by means of external reservoirs placed at suitable distances (say 500m) along the route of the cable. Oil under pressure compresses the layers of paper insulation and is forced into any voids that may have formed between the layers. Due to the elimination of voids, oil-filled cables can be used for higher voltages, the range being from 66 kV up to 230 kV. Oil-filled cables are of three types viz., single-core conductor channel, single-core sheath channel and three-core filler-space channels. Fig. 11.6 shows the constructional details of a single-core conductor channel, oil filled cable. The oil channel is formed at the centre by stranding the conductor wire around a hollow cylindrical steel spiral

tape. The oil under pressure is supplied to the channel by means of external reservoir. As the channel is made of spiral steel tape, it allows the oil to percolate between copper strands to the wrapped insulation. The oil pressure compresses the layers of paper insulation and prevents the possibility of void formation. The system is so designed that when the oil gets expanded due to increase in cable temperature, the extra oil collects in the reservoir. However, when the cable temperature falls during light load conditions, the oil from the reservoir flows to the channel. The disadvantage of this type of cable is that the channel is at the middle of the cable and is at full voltage w.r.t. earth, so that a very complicated system of joints is necessary.

Fig. 11.7 shows the constructional details of a single-core sheath channel oil-filled cable. In this type of cable, the conductor is solid similar to that of solid cable and is paper insulated. However, oil ducts are provided in the metallic sheath as shown. In the 3-core oil-filled cables shown

DIELECTRIC STRESS IN CABLE:



Under operating conditions, the insulation of a cable is subjected to electrostatic forces. This is known as dielectric stress. The dielectric stress at any point in a cable is in fact the potential gradient (or electric intensity) at that point. Consider a single core cable with core diameter d and internal sheath diameter D . The electric intensity at a point x meters from the centre of the cable is

$$E_x = \frac{Q}{2\pi\epsilon_0\epsilon_r x} \text{ volts/m}$$

By definition, electric intensity is equal to potential gradient. Therefore, potential gradient g at a point x meters from the Centre of cable is

$$g = E_x$$

$$g = \frac{E}{2\pi\epsilon_0\epsilon_r x} \text{ volts/m}$$

Potential difference V between conductor and sheath is

$$V = \frac{Q}{2\pi\epsilon_0\epsilon_r} \ln \frac{D}{d} \text{ volts}$$

$$Q = \frac{2\pi\epsilon_0\epsilon_r V}{\ln \frac{D}{d}}$$

Substituting the value of Q, we get

$$g = \frac{V}{x \ln \frac{D}{d}} \text{ volts/m}$$

It is clear from the above equation that potential gradient varies inversely as the distance x. Therefore, potential gradient will be maximum when x is minimum i.e., when $x = d/2$ or at the surface of the conductor. On the other hand, potential gradient will be minimum at $x = D/2$ or at sheath surface. Maximum potential gradient is

$$g_{\max} = \frac{2V}{d \ln \frac{D}{d}} \text{ volts/m}$$

Minimum potential gradient is

$$g_{\min} = \frac{2V}{D \ln \frac{D}{d}} \text{ volts/m}$$

$$\frac{g_{\max}}{g_{\min}} = \frac{D}{d}$$

The variation of stress in the dielectric is shown in Fig.14. It is clear that dielectric stress is maximum at the conductor surface and its value goes on decreasing as we move away from the conductor. It may be noted that maximum stress is an important consideration in the design of a cable. For instance, if a cable is to be operated at such a voltage that maximum stress is 5 kV/mm, then the insulation used must have a dielectric strength of at least 5 kV/mm, otherwise breakdown of the cable will become inevitable.

MOST ECONOMICAL SIZE OF CONDUCTOR:

It has already been shown that maximum stress in a cable occurs at the surface of the conductor. For safe working of the cable, dielectric strength of the insulation should be more than the maximum stress. Rewriting the expression for maximum stress, we get,

$$g_{\max} = \frac{2V}{d \ln \frac{D}{d}} \text{ volts/m}$$

The values of working voltage V and internal sheath diameter D have to be kept fixed at certain values due to design considerations. This leaves conductor diameter d to be the only variable. For given values of V and D, the most economical conductor diameter will be one for which g_{\max} has a minimum value. The value of g_{\max} will be minimum when $d \ln D/d$ is maximum i.e.

$$\frac{d}{dd} \left[d \ln \frac{D}{d} \right] = 0$$

$$\frac{D}{d} = e = 2.718$$

Most economical conductor diameter is

$$d = \frac{D}{2.718}$$

And the value of g_{\max} under this condition is

$$g_{\max} = \frac{2V}{d} \text{ volts/m}$$

GRADING OF CABLES:

The process of achieving uniform electrostatic stress in the dielectric of cables is known as grading of cables. It has already been shown that electrostatic stress in a single core cable has a maximum value (g_{\max}) at the conductor surface and goes on decreasing as we move towards the sheath. The maximum voltage that can be safely applied to a cable depends upon g_{\max} i.e., electrostatic stress at the conductor surface. For safe working of a cable having homogeneous dielectric, the strength of dielectric must be more than g_{\max} . If a dielectric of high strength is used for a cable, it is useful only near the conductor where stress is maximum. But as we move away from the conductor, the electrostatic stress decreases, so the dielectric will be unnecessarily over strong. The unequal stress distribution in a cable is undesirable for two reasons. Firstly, insulation of greater thickness is required which increases the cable size.


Secondly, it may lead to the breakdown of insulation. In order to overcome above disadvantages, it is necessary to have a uniform stress distribution in cables. This can be achieved by distributing the stress in such a way that its value is increased in the outer layers of dielectric. This is known as grading of cables.

The following are the two main methods of grading of cables:

- i. Capacitance grading
- ii. Intersheath grading

Capacitance Grading:

The process of achieving uniformity in the dielectric stress by using layers of different dielectrics is known as capacitance grading. In capacitance grading, the homogeneous dielectric is replaced by a composite dielectric. The composite dielectric consists of various layers of different dielectrics in such a manner that relative permittivity ϵ_r of any layer is inversely proportional to its distance from the center. Under such conditions, the value of potential gradient any point in the dielectric is constant and is independent of its distance from the center. In other words, the dielectric stress in the cable is same everywhere and the grading is ideal one. However, ideal grading requires the use of an infinite number of dielectrics which is an impossible task. In practice, two or three dielectrics are used in the decreasing order of permittivity, the dielectric of highest permittivity being used near the core. The capacitance grading can be explained beautifully by referring to the above Figure. There are three dielectrics of outer diameter d_1 , d_2 and D and of relative permittivity ϵ_1 , ϵ_2 and ϵ_3 respectively. If the permittivity are such that $\epsilon_1 > \epsilon_2 > \epsilon_3$ and the three dielectrics are worked at the same maximum stress, then



Capacitance grading

$$\epsilon_1 d = \epsilon_2 d_1 = \epsilon_3 d_2$$

$$V_1 = \frac{g_{\max}}{2} d \ln \frac{d_1}{d}$$

$$V_2 = \frac{g_{\max}}{2} d_1 \ln \frac{d_2}{d_1}$$


$$V_3 = \frac{g_{\max}}{2} d_2 \ln \frac{D}{d_2}$$

Total p.d. between core and earthed sheath is

$$V = V_1 + V_2 + V_3$$

$$V = \frac{g_{\max}}{2} \left[d \ln \frac{d_1}{d} + d_1 \ln \frac{d_2}{d_1} + d_2 \ln \frac{D}{d_2} \right]$$

Intersheath Grading: In this method of cable grading, a homogeneous dielectric is used, but it is divided into various layers by placing metallic intersheaths between the core and lead sheath. The intersheaths are held at suitable potentials which are in between the core potential and earth potential. This arrangement improves voltage distribution in the dielectric of the cable and consequently more uniform potential gradient is obtained.



Intersheath grading

Consider a cable of core diameter d and outer lead sheath of diameter D . Suppose that two intersheaths of diameters d_1 and d_2 are inserted into the homogeneous dielectric and maintained at some fixed potentials. Let V_1 , V_2 and V_3 respectively be the voltage between core and Intersheath 1, between inter sheath 1 and 2 and between inter sheath 2 and outer lead sheath.

As there is a definite potential difference between the inner and outer layers of each inter sheath, therefore, each sheath can be treated like a homogeneous single core cable Maximum stress between core and inter sheath 1 is

$$g_{1max} = \frac{V_1}{\frac{d}{2} \log_e \frac{d_1}{d}}$$

$$g_{2max} = \frac{V_2}{\frac{d_1}{2} \log_e \frac{d_2}{d_1}}$$

$$g_{3max} = \frac{V_3}{\frac{d_2}{2} \log_e \frac{D}{d_2}}$$

Since the dielectric is homogeneous, the maximum stress in each layer is the same i.e.,

$$g_{1max} = g_{2max} = g_{3max} = g_{max}$$

$$\frac{V_1}{\frac{d}{2} \ln \frac{d_1}{d}} = \frac{V_2}{\frac{d_1}{2} \ln \frac{d_2}{d_1}} = \frac{V_3}{\frac{d_2}{2} \ln \frac{D}{d_2}}$$

As the cable behaves like three capacitors in series, therefore, all the potentials are in phase i.e. Voltage between conductor and earthed lead sheath is

$$V = V_1 + V_2 + V_3$$


Inter sheath grading has three principal disadvantages. Firstly, there are complications in fixing the sheath potentials. Secondly, the inter sheaths are likely to be damaged during transportation and installation which might result in local concentrations of potential gradient. Thirdly, there are considerable losses in the inter sheaths due to charging currents. For these reasons, inter sheath grading is rarely used.

MEASUREMENT OF CAPACITANCE OF 3-CORECABLES:

In three-core cables, capacitance does not have a single value, but can be lumped as shown in belowfigure.

Capacitance between each core and sheath = C_s

Capacitance between cores = C




Cable Capacitance

These can be separated from measurements as described in the following section.

- a) Strap the 3 cores together and measure the capacitance between this bundle and the sheath as shown in figure.

Measured value = $C_{m1} = 3C_s$

This gives the capacitance to the sheath as $C_s = C_{m1}/3$




Capacitance Measurement

- b) Connect 2 of the cores to the sheath and measure between the remaining core and the sheath.

Measured value $C_{m2} = 2C + C_s$

i.e. $C = (C_{m2} - C_s)/2 = (3C_{m2} - C_{m1})/6$

Which gives the capacitance between the conductors.




Capacitance Measurement

The effective capacitance to neutral C_0 of any of the cores may be obtained by considering the star equivalent. This gives

$$C_0 = C_s + 3C = \frac{1}{3}C_{m1} + 3 \frac{3C_m^2 - C_m^1}{6}$$

$$C_0 = \frac{3}{2}C_m^2 - \frac{1}{6}C_m^1$$



Calculation of C_0


In the breakdown of actual 3-core belted cables, it is generally observed that charring occurs at those places where the stress is tangential to the layers of paper. Thus for the insulation to be effective, the tangential stresses in paper insulation should be preferably avoided. This can usually be accomplished only screening each core separately (or by having individual lead sheaths for each of the cores), so that the cable in effect becomes 3 individual cables laid within the same protective covering.

UNIT – IV

MECHANICAL DESIGN OF TRANSMISSION LINES

SAG IN OVERHEAD TRANSMISSIONLINE:

While erecting an overhead line, it is very important that conductors are under safe tension. If the conductors are too much stretched between supports in a bid to save conductor material, the stress in the conductor may reach unsafe value and in certain cases the conductor may break due to excessive tension. In order to permit safe tension in the conductors, they are not fully stretched but are allowed to have a dip or sag. The difference in level between points of supports and the lowest point on the conductor is called sag. Following Fig. 8.1 shows a conductor suspended between two equal level supports A and B. The conductor is not fully stretched but is allowed to have a dip. The lowest point on the conductor is O and the sag is S.



Sag in a transmission line

The following points may be noted:


- When the conductor is suspended between two supports at the same level, it takes the shape of catenary. However, if the sag is very small compared with the span, then sag-span curve is like a parabola.
- The tension at any point on the conductor acts tangentially. Thus tension T_0 at the lowest Point O acts horizontally as shown in Fig.(ii).
- The horizontal component of tension is constant throughout the length of the wire.
- The tension at supports is approximately equal to the horizontal tension acting at any point on the wire. Thus if T is the tension at the support B, then $T = T_0$.

Conductor sag and tension. This is an important consideration in the mechanical design of overhead lines. The conductor sag should be kept to a minimum in order to reduce the conductor material required and to avoid extra pole height for sufficient clearance above ground level. It is also desirable that tension in the conductor should be low to avoid the mechanical failure of conductor and to permit the use of less strong supports. However, low conductor tension and minimum sag are not possible. It is because low sag means a tight wire and high tension, whereas a low tension means a loose wire and increased sag. Therefore, in actual practice, a compromise is made between the two.

Calculation of Sag: In an overhead line, the sag should be so adjusted that tension in the conductors is within safe limits. The tension is governed by conductor weight, effects of wind, ice loading and temperature variations. It is a standard practice to keep conductor tension less than 50% of its ultimate tensile strength i.e., minimum factor of safety in respect of conductor tension should be 2. We shall now calculate sag and tension of a conductor when (i) supports are at equal levels and (ii) supports are at unequal levels.

CALCULATION OF SAG WHEN SUPPORTS ARE AT EQUALLEVELS:

Consider a conductor between two equi-level supports A and B with O as the lowest point as shown in Fig.. It can be proved that lowest point will be at a conductor between two equ-ilevel supports A and B with O as the lowest point as shown in Fig.. It can be proved that lowest point will be at themid-span.



Sag Calculation

A conductor between two equilevel supports A and B with O as the lowest point as shown in Fig.. It can be proved that lowest point will be at the mid-span.

Let l = Length of span

w = Weight per unit length of conductor

T = Tension in the conductor.

Consider a point P on the conductor. Taking the lowest point O as the origin, let the co-ordinates of point P be x and y . Assuming that the curvature is so small that curved length is equal to its horizontal projection (i.e., $OP = x$), the two forces acting on the portion OP of the conductor are :

- The weight $w x$ of conductor acting at a distance $x/2$ from O.
- The tension T acting at O.

Equating the moments of above two forces about point O, we get,

$$T y = w x \times \frac{x}{2}$$

$$y = \frac{w x^2}{2T}$$

The maximum dip (sag) is represented by the value of y at either of the supports A & B.

At supports A

$$y = \frac{w l^2}{8T}$$


and

$$S = \frac{w l^2}{8T}$$

EFFECT OF WIND AND ICELOADING:

The above formulae for sag are true only in still air and at normal temperature when the conductor is acted by its weight only. However, in actual practice, a conductor may have ice coating and simultaneously subjected to wind pressure. The weight of ice acts vertically downwards i.e., in the same direction as the weight of conductor. The force due to the wind is assumed to act horizontally i.e., at right angle to the

projected surface of the conductor. Hence, the total force on the conductor is the vector sum of horizontal and vertical forces as shown in Fig



Effect of Ice and Wind

Total weight of conductor per unit length is

$$w_t = \sqrt{(w + w_i)^2 + w_w^2}$$

Where w = weight of conductor per unit length

= conductor material density \times volume per unit length

w_i = weight of ice per unit length

= density of ice \times volume of ice per unit length

$$= \text{density of ice} \times \frac{\pi}{4} d^2 + 2t - \pi^2 \times 1$$

w_w = wind force per unit length

= wind pressure per unit area \times projected area per unit length

$$= \text{wind pressure} \times [(d+2t) \times 1]$$

VIBRATION DAMPER:

Aeolian vibrations mostly occur at steady wind velocities from 1 to 7 m/s. With increasing wind turbulences the wind power input to the conductor will decrease. The intensity to induce vibrations depends on several parameters such as type of conductors and clamps, tension, span length, topography in the surrounding, height and direction of the line as well as the frequency of occurrence of the vibration induced wind streams.


In the wake of wind power plants (up to 3 x diameter of the rotor behind the plant) the wind velocity will be reduced up to 0,5 of the velocity of the free wind stream, so that lower wind velocities could be expected more frequently here. That's why the probability of a higher stresses for the conductors caused by wind-induced vibrations will be greater than without wind powerplants.

On the other hand the intensity of turbulences will increase which will hinder the arising of vibrations. The both important parameters for inducing vibrations, wind velocity and turbulence intensity, depends on the distance to the rotor and the height of it.

The investigations showed an increasing of damage probability on OHTL due to the wake of wind power plants of the factor 2,5 to 3,5 between one and three rotor diameters behind the plant which will cause an equivalent decreasing of lifetime of conductors and earth wires.

STRINGINGCHART:


For use in the field work of stringing the conductors, temperature-sag and temperature tension charts are plotted for the given conductor and loading conditions. Such curves are called stringing charts. These charts are very helpful while stringing overhead lines.



Stringing Chart

SAGTEMPLATE:

A Sag Template is a very important tool with the help of which the position of towers on the Profile is decided so that they conform to the limitations of vertical and wind loads on any particular tower, and minimum clearances, as per I.E. Rules, required to be maintained between the line conductor to ground, telephone lines, buildings, streets, navigable canals, power lines, or any other object coming under or near the line.



A Sag Template is specific for the particular line voltage, the conductor used and the applicable design conditions. Therefore, the correct applicable Sag Template should be used. A Sag Template consists of a set of parabolic curves drawn on transparent celluloid or a acrylic clear sheet duly cut in over the maximum conductor sag curve to allow the conductor curve to be drawn and the lowest points of the conductor sag to be marked on the profile when the profile is placed underneath it.

The set of curves in the sag template consists of:

- (1). Cold or Uplift Curve‘ showing sag of conductor at minimum temperature (minus 2.5°C) and still wind.
- (2). Hot or Maximum Sag Curve‘ showing maximum sag of conductor at maximum temperature and still wind including sag tolerances allowed (normally 4%), if any, and under maximum ice condition wherever applicable.
- (3). Ground Clearance Curve‘ which is drawn parallel to the Hot or Maximum Sag Curve‘ and at a distance equal to the specified minimum ground clearance for the relevant voltage.
- (4). Tower Footing Curve‘ which is drawn parallel to the Ground Clearance Curve‘ and separated by a minimum distance equal to the maximum sag at the basic design span.


UNIT – V

DISTRIBUTION SYSTEMS

DISTRIBUTION SYSTEM:

That part of power system which distributes electric power for local use is known as distribution system. In general, the distribution system is the electrical system between the sub-station fed by the distribution system and the consumer's meters. It generally consists of feeders, distributors and the service mains.

(i) **Feeders:** A feeder is a conductor which connects the sub-station (or localized generating station) to the area where power is to be distributed. Generally, no tapping's are taken from the feeder so that current in it remains the same throughout. The main consideration in the design of a feeder is the current carrying capacity.



(ii) **Distributor.** A distributor is a conductor from which tapplings are taken for supply to the consumers. In Fig. 12.1, AB, BC, CD and DA are the distributors. The current through a distributor is not constant because tapplings are taken at various places along its length. While designing a distributor, voltage drop along its length is the main consideration since the statutory limit of voltage variations is $\pm 6\%$ of rated value at the consumers' terminals.

- i. **Service mains.** A service mains is generally a small cable which connects the distributor to the consumers' terminals.

Classification of Distribution Systems

A distribution system may be classified according to ;

- (i) *Nature of current.* According to nature of current, distribution system may be classified as (a) d.c. distribution system (b) a.c. distribution system.

Now-a-days, a.c. system is universally adopted for distribution of electric power as it is simpler and more economical than direct current method.

- ii. *Type of construction.* According to type of construction, distribution system may be classified as (a) overhead system (b) underground system. The overhead system is generally employed for distribution as it is 5 to 10 times cheaper than the equivalent underground system. In general, the

underground system is used at places where overhead construction is impracticable or prohibited by the local laws.

- iii. Scheme of connection. According to scheme of connection, the distribution system may be classified as (a) radial system (b) ring main system (c) inter-connected system. Each scheme has its own advantages and disadvantages


A.C.DISTRIBUTION

- i. Now-a-days electrical energy is generated, transmitted and distributed in the form of alternating current.
- ii. Alternating current is preferred to direct current is the fact that alternating voltage can be conveniently changed by means of a transformer.
- iii. High distribution and distribution voltages have greatly reduced the current in the conductors and the resulting line losses.
- iv. The A.C. distribution system is the electrical system between the step-down substation fed by the distribution system and the consumers' meters.

The A.C. distribution system is classified into

- (i) Primary distribution system and
- (ii) Secondary distribution system.

PRIMARY DISTRIBUTION SYSTEM:




It is that part of A.C. distribution system which operates at voltages somewhat higher than general utilization than the average low-voltage consumer uses.

The most commonly used primary distribution voltages are 11 kV, 6.6 kV and 3.3 kV

Primary distribution is carried out by 3-phase, 3-wire system. Fig. shows a typical primary distribution system. Electric power from the generating station is transmitted at high voltage to the substation located

in or near the city. At this substation, voltage is stepped down to 11 kV with the help of step-down transformer. Power is supplied to various substations for distribution or to big consumers at this voltage. This forms the high voltage distribution or primary distribution.

SECONDARY DISTRIBUTION SYSTEM:



It is that part of a.c. distribution system employs 400/230 V, 3-phase, 4-wire system.

shows a typical secondary distribution system.

The primary distribution circuit delivers power to various substations, called distribution substations. The substations are situated near the consumers' localities and contain step down transformers.

At each distribution substation, the voltage is stepped down to 400 V and power is delivered by 3-phase, 4-wire a.c. system.

The voltage between any two phases is 400 V and between any phase and neutral is 230 V.

The single phase domestic loads are connected between any one phase and the neutral, Motor loads are connected across 3-phase lines directly.

D.C.DISTRIBUTION:

For certain applications, d.c. supply is absolutely necessary. d.c. supply is required for the operation of variable speed machinery (*i.e.*, d.c. motors storage battery).


For this purpose, A.C. power is converted into D.C. power at the substation by using converting machinery *e.g.*, mercury arc rectifiers, rotary converters and motor-generator sets.

The D.C. supply obtained in the form of (i) 2-wire or (ii) 3-wire for distribution.

i. 2-Wire D.C. System

- As the name implies, this system of distribution consists of two wires.
- One is the outgoing or positive wire and the other is the return or negative wire.
- The loads such as lamps, motors etc. are connected in parallel between the two wires as shown in Fig.

This system is never used for distribution purposes due to low efficiency but may be employed for distribution of d.c. power.



ii. 3-wire D.C. system.

- It consists of two outers and a middle or neutral wire which is earthed at the substation.
- The voltage between the outers is twice the voltage between either outer or neutral.
- The principal advantage of this system is that it makes available two voltages at the consumer terminals,
- V between any outer and the neutral and $2V$ between the outers.

COMPARISON OF D.C. AND A.C. DISTRIBUTION:

The electric power can be distributed either by means of D.C. or A.C. Each system has its own merits and demerits.

D.C. DISTRIBUTION:

• **Advantages.**

- (1). It requires only two conductors as compared to three for A.C. distribution.
- (2). There is no inductance, capacitance, phase displacement and surge problems in D.C. distribution.
- (3). Due to the absence of inductance, the voltage drop in a D.C. distribution line is less than the A.C. line for the same load and sending end voltage. For this reason, a D.C. distribution line has better voltage regulation.
- (4). There is no skin effect in a D.C. system. Therefore, entire cross-section of the line conductor is utilized.
- (5). For the same working voltage, the potential stress on the insulation is less in case of D.C. system than that in A.C. system. Therefore, a D.C. line requires less insulation.
- (6). A D.C. line has less corona loss and reduced interference with communication circuits.
- (7). The high voltage D.C. distribution is free from the dielectric losses, particularly in (viii) In D.C. distribution; there are no stability problems and synchronizing difficulties.

- **Disadvantages**

- (1). Electric power cannot be generated at high D.C. voltage due to commutation problems.
- (2). The D.C. voltage cannot be stepped up for distribution of power at high voltages.
- (3). The D.C. switches and circuit breakers have their own limitations.

A.C.DISTRIBUTION:

- **Advantages**

- (1). The power can be generated at high voltages.
- (2). The maintenance of A.C. sub-stations is easy and cheaper.
- (3). The A.C. voltage can be stepped up or stepped down by transformers with ease and efficiency.

This permits to transmit power at high voltages and distribute it at safe potentials.

- **Disadvantages**

- (1). An A.C. line requires more copper than a D.C. line.
- (2). The construction of A.C. distribution line is more complicated than a D.C. distribution line.
- (3). Due to skin effect in the A.C. system, the effective resistance of the line is increased.
- (4). An A.C. line has capacitance. Therefore, there is a continuous loss of power due to charging current even when the line is open.

OVERHEAD VERSUS UNDERGROUND SYSTEM:

The distribution system can be overhead or underground.

Overhead lines are generally mounted on wooden, concrete or steel poles which are arranged to carry distribution transformers in addition to the conductors.

The underground system uses conduits, cables and manholes under the surface of streets and sidewalks.

The choice between overhead and underground system depends upon a number of widely differing factors.

- Public Safety:** The underground system is more safe than overhead system because all distribution wiring is placed underground and there are little chances of any hazard.
- Initial Cost:** The underground system is more expensive due to the high cost of trenching, conduits, cables, manholes and other special equipment. The initial cost of an underground system may be five to ten times than that of an overhead system.
- Flexibility:** The overhead system is much more flexible than the underground system. In the latter case, manholes, duct lines etc., are permanently placed once installed and the load expansion can only be met by laying new lines. However, on an overhead system, poles, wires, transformers etc., can be easily shifted to meet the changes in load conditions.
- Faults:** The chances of faults in underground system are very rare as the cables are laid underground and are generally provided with better insulation.
- Appearance:** The general appearance of an underground system is better as all the distribution lines are invisible. This factor is exerting considerable public pressure on electric supply companies to switch over to underground system.

- f) **Fault Location And Repairs:** In general, there are little chances of faults in an underground system. However, if a fault does occur, it is difficult to locate and repair on this system. On an overhead system, the conductors are visible and easily accessible so that fault locations and repairs can be easily made.
- g) **Current Carrying Capacity And Voltage Drop:** An overhead distribution conductor has a considerably higher current carrying capacity than an underground cable conductor of the same material and cross-section. On the other hand, underground cable conductor has much lower inductive reactance than that of an overhead conductor because of closer spacing of conductors.
- h) **Useful Life:** The useful life of underground system is much longer than that of an overhead system. An overhead system may have a useful life of 25 years, whereas an underground system may have a useful life of more than 50 years.
- i) **Maintenance Cost:** The maintenance cost of underground system is very low as compared with that of overhead system because of less chance of faults and service interruptions from wind, ice, and lightning as well as from traffic hazards.
- j) **Interference With Communication Circuit:** An overhead system causes electromagnetic interference with the telephone lines. The power line currents are superimposed on speech currents, resulting in the potential of the communication channel being raised to an undesirable level. However, there is no such interference with the underground system.

It is clear from the above comparison that each system has its own advantages and disadvantages.

DESIGN CONSIDERATIONS IN DISTRIBUTION SYSTEM:

Good voltage regulation of a distribution network is probably the most important factor responsible for delivering good service to the consumers. For this purpose, design of feeders and distributors requires careful consideration.

- a) **Feeders:** A feeder is designed from the point of view of its current carrying capacity while the voltage drop consideration is relatively unimportant. It is because voltage drop in a feeder can be compensated by means of voltage regulating equipment at the substation.
- b) **Distributors:** A distributor is designed from the point of view of the voltage drop in it. It is because a distributor supplies power to the consumers and there is a statutory limit of voltage variations at the consumer's terminals ($\pm 6\%$ of rated value). The size and length of the distributor should be such that voltage at the consumer's terminals is within the permissible limits.

REQUIREMENTS OF A DISTRIBUTION SYSTEM:

Requirements of a good distribution system are : proper voltage, availability of power on demand and reliability.

- I. **Proper voltage:** One important requirement of a distribution system is that voltage variations at consumer's terminals should be as low as possible. The changes in voltage are generally caused due to the variation of load on the system. Low voltage causes loss of revenue, inefficient lighting and possible burning out of motors. High voltage causes lamps to burn out permanently and may cause failure of other appliances. Therefore, a good distribution system


should ensure that the voltage variations at consumers terminals are within permissible limits. The statutory limit of voltage variations is $\pm 6\%$ of the rated value at the consumer's terminals. Thus, if the declared voltage is 230 V, then the highest voltage of the consumer should not exceed 244 V while the lowest voltage of the consumer should not be less than 216 V.


- II. **Availability of power on demand:** Power must be available to the consumers in any amount that they may require from time to time. For example, motors may be started or shut down, lights may be turned on or off, without advance warning to the electric supply company. As electrical energy cannot be stored, therefore, the distribution system must be capable of supplying load demands of the consumers. This necessitates that operating staff must continuously study load patterns to predict in advance those major load changes that follow the known schedules.
- III. **Reliability:** Modern industry is almost dependent on electric power for its operation. Homes and office buildings are lighted, heated, cooled and ventilated by electric power. This calls for reliable service. Unfortunately, electric power, like everything else that is man-made, can never be absolutely reliable. However, the reliability can be improved to a considerable extent by (a) interconnected system (b) reliable automatic control system (c) providing additional reserve facilities.

CONNECTION SCHEMES OF DISTRIBUTION SYSTEM:

RADIAL SYSTEM:

1. In this system, separate feeders radiate from a single substation and feed the distributors at one end only.
2. Fig.(i) Shows a single line diagram of a radial system or D.C. distribution where a feeder OC supplies a distributor AB at point A. distributor is fed at one end only i.e., point A is this case.
3. Fig. (ii) Shows a single line diagram of radial system for A.C. distribution.





This is the simplest distribution circuit and has the lowest initial cost.

Drawbacks:


1. The end of the distributor nearest to the feeding point will be heavily loaded.
2. any fault on the feeder or distributor cuts off supply to the consumers who are on the side of the fault.
3. The consumers at the distant end of the distributor would be subjected to serious voltage fluctuations when the load on the distributor changes.
4. Due to these limitations, this system is used for short distances only.

RING MAIN SYSTEM:

1. In this system, the primaries of distribution transformers form a loop
2. The loop circuit starts from the substation bus-bars, makes a loop through the area to be served, and returns to the substation.
3. Fig. 12.9 shows the single line diagram of ring main system for a.c. distribution where substation supplies to the closed feeder LMNOPQRS.
4. The distributors are tapped from different points M , O and Q of the feeder through distribution transformers.


Advantages:

- a) There are less voltage fluctuations at consumer's terminals.
- b) The system is very reliable as each distributor is fed via two feeders. In the event of fault on any section of the feeder, the continuity of supply is maintained.



INTERCONNECTED SYSTEM:

- When the feeder ring is energized by two or more than two generating stations or substations, it is called inter-connected system.
- Fig.12.10 shows the single line diagram of an inter-connected system where the closed feeder ring ABCD is supplied by two substations S_1 and S_2 at points D and C respectively.
- Distributors are connected to points O, P, Q and R of the feeder ring through distribution transformers.




Advantages:

- It increases the service reliability.
- Any area fed from one generating station during peak load hours can be fed from the other generating station. This reduces reserve power capacity and increases efficiency of the system.

A.C. DISTRIBUTION VOLTAGE CALCULATIONS:

In A.C. distribution calculations, power factors of various load currents have to be considered since currents in different sections of the distributor will be the vector sum of load currents and not the arithmetic sum. The power factors of load currents may be given (i) *w.r.t.* receiving or sending end voltage or (ii) *w.r.t.* to load voltage itself. Each case shall be discussed separately.

(i) **Power factors referred to receiving end Voltage.** Consider an A.C. distributor AB with concentrated loads of I_1 and I_2 tapped off at points C and B as shown in Fig. Taking the receiving end voltage V_B as the reference Let R_1, X_1 and R_2, X_2 be the resistance and reactance of sections AC and CB of the distributor.



$$\text{Impedance of section } AC, \quad \overrightarrow{Z_{AC}} = R_1 + j X_1$$

$$\text{Impedance of section } CB, \quad \overrightarrow{Z_{CB}} = R_2 + j X_2$$

$$\text{Load current at point } C, \quad \overrightarrow{I_1} = I_1 (\cos \phi_1 - j \sin \phi_1)$$

$$\text{Load current at point } B, \quad \overrightarrow{I_2} = I_2 (\cos \phi_2 - j \sin \phi_2)$$

$$\text{Current in section } CB, \quad \overrightarrow{I_{CB}} = \overrightarrow{I_2} = I_2 (\cos \phi_2 - j \sin \phi_2)$$

$$\begin{aligned} \text{Current in section } AC, \quad \overrightarrow{I_{AC}} &= \overrightarrow{I_1} + \overrightarrow{I_2} \\ &= I_1 (\cos \phi_1 - j \sin \phi_1) + I_2 (\cos \phi_2 - j \sin \phi_2) \end{aligned}$$

$$\text{Voltage drop in section } CB, \quad \overrightarrow{V_{CB}} = \overrightarrow{I_{CB}} \overrightarrow{Z_{CB}} = I_2 (\cos \phi_2 - j \sin \phi_2) (R_2 + j X_2)$$

$$\text{Voltage drop in section } AC, \quad \overrightarrow{V_{AC}} = \overrightarrow{I_{AC}} \overrightarrow{Z_{AC}} = (\overrightarrow{I_1} + \overrightarrow{I_2}) \overrightarrow{Z_{AC}}$$

$$= [I_1 (\cos \phi_1 - j \sin \phi_1) + I_2 (\cos \phi_2 - j \sin \phi_2)] [R_1 + j X_1]$$

$$\text{Sending end voltage,} \quad \overrightarrow{V_A} = \overrightarrow{V_B} + \overrightarrow{V_{CB}} + \overrightarrow{V_{AC}}$$

$$\text{Sending end current,} \quad \overrightarrow{I_A} = \overrightarrow{I_1} + \overrightarrow{I_2}$$




Fig. 14.2

(ii) **Power factors referred to respective load voltages.** Suppose the power factors of loads in the previous Fig. 14.1 are referred to their respective load voltages. Then ϕ_1 is the phase angle between V_C and I_1 and ϕ_2 is the phase angle between V_B and I_2 . The vector diagram under these conditions is shown in Fig. 14.3.




Fig. 14.3

$$\text{Voltage drop in section } CB = \vec{I}_2 \vec{Z}_{CB} = I_2 (\cos \phi_2 - j \sin \phi_2) (R_2 + j X_2)$$

$$\text{Voltage at point } C = \vec{V}_B + \text{Drop in section } CB = V_C \angle \alpha \text{ (say)}$$

$$\text{Now } \vec{I}_1 = I_1 \angle -\phi_1 \text{ w.r.t. voltage } V_C$$

$$\therefore \vec{I}_1 = I_1 \angle -(\phi_1 - \alpha) \text{ w.r.t. voltage } V_B$$

$$\text{i.e. } \vec{I}_1 = I_1 [\cos (\phi_1 - \alpha) - j \sin (\phi_1 - \alpha)]$$

$$\text{Now } \vec{I}_{AC} = \vec{I}_1 + \vec{I}_2$$

$$= I_1 [\cos (\phi_1 - \alpha) - j \sin (\phi_1 - \alpha)] + I_2 (\cos \phi_2 - j \sin \phi_2)$$

$$\text{Voltage drop in section } AC = \vec{I}_{AC} \vec{Z}_{AC}$$

$$\text{Voltage at point } A = V_B + \text{Drop in } CB + \text{Drop in } AC$$

Example 14.1. A single phase a.c. distributor AB 300 metres long is fed from end A and is loaded as under :


(i) 100 A at 0.707 p.f. lagging 200 m from point A

(ii) 200 A at 0.8 p.f. lagging 300 m from point A

The load resistance and reactance of the distributor is 0.2Ω and 0.1Ω per kilometre. Calculate the total voltage drop in the distributor. The load power factors refer to the voltage at the far end.

Solution. Fig. 14.4 shows the single line diagram of the distributor.

$$\text{Impedance of distributor/km} = (0.2 + j 0.1) \Omega$$



$$\text{Impedance of section AC, } \overrightarrow{Z_{AC}} = (0.2 + j 0.1) \times 200/1000 = (0.04 + j 0.02) \Omega$$

$$\text{Impedance of section CB, } \overrightarrow{Z_{CB}} = (0.2 + j 0.1) \times 100/1000 = (0.02 + j 0.01) \Omega$$

Taking voltage at the far end B as the reference vector, we have,

$$\begin{aligned} \text{Load current at point B, } \overrightarrow{I_2} &= I_2 (\cos \phi_2 - j \sin \phi_2) = 200 (0.8 - j 0.6) \\ &= (160 - j 120) \text{ A} \end{aligned}$$

$$\begin{aligned} \text{Load current at point C, } \overrightarrow{I_1} &= I_1 (\cos \phi_1 - j \sin \phi_1) = 100 (0.707 - j 0.707) \\ &= (70.7 - j 70.7) \text{ A} \end{aligned}$$

$$\text{Current in section CB, } \overrightarrow{I_{CB}} = \overrightarrow{I_2} = (160 - j 120) \text{ A}$$

$$\begin{aligned} \text{Current in section AC, } \overrightarrow{I_{AC}} &= \overrightarrow{I_1} + \overrightarrow{I_2} = (70.7 - j 70.7) + (160 - j 120) \\ &= (230.7 - j 190.7) \text{ A} \end{aligned}$$

$$\begin{aligned} \text{Voltage drop in section CB, } \overrightarrow{V_{CB}} &= \overrightarrow{I_{CB}} \overrightarrow{Z_{CB}} = (160 - j 120) (0.02 + j 0.01) \\ &= (4.4 - j 0.8) \text{ volts} \end{aligned}$$

$$\begin{aligned} \text{Voltage drop in section AC, } \overrightarrow{V_{AC}} &= \overrightarrow{I_{AC}} \overrightarrow{Z_{AC}} = (230.7 - j 190.7) (0.04 + j 0.02) \\ &= (13.04 - j 3.01) \text{ volts} \end{aligned}$$

$$\text{Voltage drop in the distributor} = \overrightarrow{V_{AC}} + \overrightarrow{V_{CB}} = (13.04 - j 3.01) + (4.4 - j 0.8)$$

$$\text{Magnitude of drop} = \sqrt{(17.44)^2 + (3.81)^2} = \mathbf{17.85 \text{ V}}$$

Example 14.2. A single phase distributor 2 kilometres long supplies a load of 120 A at 0.8 p.f. lagging at its far end and a load of 80 A at 0.9 p.f. lagging at its mid-point. Both power factors are

referred to the voltage at the far end. The resistance and reactance per km (go and return) are 0.05Ω and 0.1Ω respectively. If the voltage at the far end is maintained at 230 V , calculate :


- (i) voltage at the sending end
- (ii) phase angle between voltages at the two ends.

Solution. Fig. 14.5 shows the distributor AB with C as the mid-point

$$\text{Impedance of distributor/km} = (0.05 + j 0.1) \Omega$$

$$\text{Impedance of section } AC, \quad \vec{Z}_{AC} = (0.05 + j 0.1) \times 1000/1000 = (0.05 + j 0.1) \Omega$$

$$\text{Impedance of section } CB, \quad \vec{Z}_{CB} = (0.05 + j 0.1) \times 1000/1000 = (0.05 + j 0.1) \Omega$$



Let the voltage V_B at point B be taken as the reference vector.

$$\text{Then,} \quad \vec{V}_B = 230 + j 0$$

$$(i) \text{ Load current at point } B, \quad \vec{I}_2 = 120 (0.8 - j 0.6) = 96 - j 72$$

$$\text{Load current at point } C, \quad \vec{I}_1 = 80 (0.9 - j 0.436) = 72 - j 34.88$$

$$\text{Current in section } CB, \quad \vec{I}_{CB} = \vec{I}_2 = 96 - j 72$$

$$\begin{aligned} \text{Current in section } AC, \quad \vec{I}_{AC} &= \vec{I}_1 + \vec{I}_2 = (72 - j 34.88) + (96 - j 72) \\ &= 168 - j 106.88 \end{aligned}$$

$$\begin{aligned} \text{Drop in section } CB, \quad \vec{V}_{CB} &= \vec{I}_{CB} \vec{Z}_{CB} = (96 - j 72) (0.05 + j 0.1) \\ &= 12 + j 6 \end{aligned}$$

$$\begin{aligned} \text{Drop in section } AC, \quad \vec{V}_{AC} &= \vec{I}_{AC} \vec{Z}_{AC} = (168 - j 106.88) (0.05 + j 0.1) \\ &= 19.08 + j 11.45 \end{aligned}$$

$$\begin{aligned} \therefore \text{ Sending end voltage, } \vec{V}_A &= \vec{V}_B + \vec{V}_{CB} + \vec{V}_{AC} \\ &= (230 + j 0) + (12 + j 6) + (19.08 + j 11.45) \\ &= 261.08 + j 17.45 \end{aligned}$$

$$\text{Its magnitude is} \quad = \sqrt{(261.08)^2 + (17.45)^2} = \mathbf{261.67 \text{ V}}$$

(ii) The phase difference θ between V_A and V_B is given by :

$$\tan \theta = \frac{17.45}{261.08} = 0.0668$$

$$\therefore \quad \theta = \tan^{-1} 0.0668 = \mathbf{3.82^\circ}$$

BASIC CONCEPT OF INTERCONNECTED SYSTEMS:

Electricity sector in India is growing at rapid pace. During the current year 2017-18 (Upto 30.11.2017), the Peak Demand is about 164.1 GW and the Installed Capacity is 330.8 GW with generation mix of Thermal (66.2%), Hydro (13.6%), Renewable 18.2%) and Nuclear (2.0%).

The natural resources for electricity generation in India are unevenly dispersed and concentrated in a few pockets. Hydro resources are located in the Himalayan foothills, North Eastern Region (NER). Coal reserves are concentrated in Jharkhand, Odisha, West Bengal, Chhattisgarh, parts of Madhya Pradesh, whereas lignite is located in Tamil Nadu and Gujarat. Also lot of power station, generating from Gas and renewable energy sources like Solar, Wind etc. have been installed in various parts of country.

Powergrid Corporation of India Limited (POWERGRID), a Central Transmission Utilities (CTU), is responsible for planning inter-state transmission system (ISTS). Similarly there are State Transmission Utilities (STU) (namely State Transco/ SEBs) responsible for the development of Intra State Transmission System.

An extensive network of Transmission lines has been developed over the years for evacuating power produced by different electricity generating stations and distributing the same to the consumers. Depending upon the quantum of power and the distance involved, lines of appropriate voltages are laid. The nominal Extra High Voltage lines in vogue are ± 800 kV HVDC & 765kV, 400 kV, 230/220 kV, 110 kV and 66kV AC lines. These have been installed by all the SEBs, and by Generation, Transmission & Distribution utilities including those in Central Sector.

13,820 circuit kilometres (ckm) of transmission lines have been commissioned during 2017-18 (April-November 2017). This is 59.9% of the annual target of 23,086 ckm fixed for 2017-18. Similarly, 50,805 MVA of transformation capacity of substations has been added during 2017-18 (April-November 2017) which constitutes 94.1% of the annual target of 53,978 MVA fixed for 2017-18.

The capacity of transmission system of 220 kV and above voltage levels, in the country as on 30th November 2017 was 3,81,671 ckm of transmission lines and 7,91,570 MVA of transformation capacity of Substations.

As on 30th November 2017, the total transmission capacity of the inter-regional links is 78,050 MW.

The transmission lines are operated in accordance with Regulations/standards of Central Electricity Authority (CEA) / Central Electricity Regulatory Commission (CERC) / State Electricity Regulatory Commissions (SERC). However, in certain cases, the loading on transmission lines may have to be restricted keeping in view the voltage stability, angular stability, loop flows, load flow pattern and grid security. Power surplus States have been inter-alia, able to supply their surplus power to power deficit State Utilities across the country except for some congestion in supply of power to Southern Region.

Power System Operation Corporation Limited (POSOCO), is managing the National and Regional grid from National Load Dispatch Centre (NLDC) and its five Regional Load Dispatch Centres (RLDC) through state-of-the-art unified load dispatch & communication facilities.

CENTRAL TRANSMISSION UTILITY (CTU):

Power Grid Corporation of India Limited (POWERGRID, the 'Central Transmission Utility (CTU)' of the country and a 'Navratna' Company operating under Ministry of Power, is engaged in power transmission business with the responsibility for planning, implementation, operation and maintenance of Inter-State Transmission System (ISTS). POWERGRID is a listed Company, with 57.90% holding of Government of India and balance by Institutional Investors & public.

POWERGRID, as on 30th September 2017, owns & operates around 1,42,989 ckm of Extra High Voltage (EHV) transmission lines spread over the length and breadth of the country and 226 EHV AC & HVDC Sub-stations with transformation capacity of more than 3,11,185 MVA. Its vast transmission network wheels more than 45% of the power in the country. The availability of this huge transmission network is consistently maintained over 99% through deployment of state-of-the-art operation & maintenance techniques at par with global standards.

During FY 2016-17, POWERGRID has achieved a turnover of about Rs. 26,581.46 Crore and Net Profit of Rs.7,520.15 Crore. As on 31.03.2017 Gross Fixed Assets of the company have also grown to Rs.1,49,730Crore.

High Capacity Power Transmission Corridors (HCPTCs) have been implemented to meet bulk power evacuation requirement of various Independent Power Producers (IPPs) mainly coming up in resource rich and coastal areas such as Chhattisgarh, Odisha, Madhya Pradesh, Sikkim, Jharkhand, Tamil Nadu and Andhra Pradesh. Implementation of these corridors has been taken up in a phased manner matching with generation projects.

The total inter-regional transmission capacity (220kV and above) of country has been enhanced from 27,150 MW to 75,050 MW from XIth to XIIth plan. This Endeavour of POWERGRID under the guidance of Ministry of Power has enabled in moderation of the prices of electricity in Northern Region and ensured reliable supply of electricity.

POWERGRID has achieved a capital investment of about Rs.1,12,600crore for development of inter-State transmission system during XII Plan against a target of Rs.1,10,000 Crore. During the XII plan it has added about 45,900 ckm of transmission line and about 1,64,000 MVA of transformation capacity against a target of 40,000 ckm and 1,00,000 MVA respectively.

The Company has an excellent credit rating with financial institutions, thereby, is placed in a comfortable position in terms of resource mobilization. POWERGRID is also playing a major role in facilitating grid interconnection of renewable generation across the country through implementation of portion of ISTS part of Green Energy Corridors.

Conserving Right-of-Way (RoW), minimizing impact on natural resources, coordinated development of cost effective transmission corridor, flexibility in up gradation of transfer capacity of lines matching with power transfer requirement are major areas of concern in development of transmission network in the country. In this direction, the Company has been working on higher transmission voltages of ± 800 kV HVDC & 1200 kV UHVAC. The ± 800 kV, 3000 MW HVDC Bi-pole line (CK-I) connecting Champa in Chhattisgarh to Kurukshetra in Haryana has been commissioned recently. This transmission system is further being upgraded to 6000 MW capacity with addition of 2nd HVDC Bipole (CK-2) of 3000 MW, ± 800 kV HVDC Terminals which is expected to be completed by December 2018. Similarly, power flow through 1200 kV National Test Station (NTS) has commenced at Bina, Madhya Pradesh.

To shore up its revenue and create value for its stakeholders, POWERGRID diversified into telecom business, leveraging its country wide transmission infrastructure. Company is providing back-bone connectivity to all metros, major cities & towns including remote areas of J&K and North-Eastern States

etc. Total network coverage is more than 41,988 kms and numbers of Points of Presence (PoPs) locations are more than 662. Having Intra city network in 105 cities across India, the Telecom Backbone Availability for the year 2016-17 was about 99.9%.

POWERGRID has successfully completed the prestigious NKN (National Knowledge Network) project devised by Govt. of India, which connects all knowledge centres across the Country such as Indian Institutes of Technology (IITs), Indian Institute of Sciences (IISCs) etc., on a high speed connectivity. A Company has signed an agreement with Bharat Sanchar Nigam Limited (BSNL) to improve the telecommunication connectivity with the North-Eastern States including Sikkim. It envisages the provisioning of bandwidth on optical fibre media laid over existing high tension electric transmission network. After completion of the proposed connectivity, the reliability of the telecom services improves substantially in North-Eastern region including Sikkim.

As a part of Government of India plan to connect 250,000 Gram Panchayats (GP) in the Country, POWERGRID one of the implementing agencies for BharatNet project and has been entrusted with the task of development and maintenance of the National Optical Fibre Network in states, namely Andhra Pradesh, Telangana, Himachal Pradesh, Jharkhand and Odisha.

Further, POWERGRID is playing a significant role in carrying forward the distribution reforms through undertaking Deendayal Upadhyaya Gram Jyoti Yojana (DDUGJY) and Integrated Power Development Scheme (IPDS) works on behalf of the Govt. of India in the country.

POWERGRID has emerged as a strong player in South Asia and is playing an active role in formation of a strong SAARC grid for effective utilization of resources for mutual benefits. Presently, various electrical interconnections exist between India & Bhutan, India & Nepal and India & Bangladesh. Further, the interconnection between India & Bhutan, India & Nepal and India & Bangladesh are being strengthened for substantial exchange of power across the borders.

POWERGRID is offering consultancy services to various National clients & International clients, including many South Asian, African, and Middle East countries.

POWERGRID is implementing the prestigious and State of the Art, Renewable Energy Management Centres (REMC) for managing the renewable generation integration and operation which shall include a host of activities from renewable energy forecasting to energy balancing and generation scheduling. In Smart transmission, POWERGRID has been implementing Synchrophasor Technology in its Wide Area Measurement System (WAMS) Project through installation of PMUs (Phasor Measurement Units) at different locations in all regions across the country, which facilitates better visualization and situational awareness of the grid events such as grid robustness, oscillations, angle/ voltage instability, system margin etc. as well as decision support tools. POWERGRID also acts as 'nodal point' in prestigious "India Smart Grid Task Force" Secretariat for Government's activities related to SmartGrid.

INDIAN ELECTRICITY RULES:

- **Cut-out on consumer's premises:**

1. The supplier shall provide a suitable cut-out in each conductor of every service-line other than an earthed or earthed neutral conductor or the earthed external conductor of a concentric cable within a consumer's premises, in an accessible position. Such cut-out shall be contained within an adequately enclosed fireproof receptacle.
2. Where more than one consumer is supplied through a common service-line, each such consumer shall be provided with an independent cut-out at the point of junction to the common service
3. Every electric supply line other than the earth or earthed neutral conductor of any system or the earthed external conductor of a concentric cable shall be protected by a suitable cut-out by its owner
4. No cut-out, link or switch other than a linked switch arranged to operate simultaneously on the earthed or earthed neutral conductor and live conductors shall be inserted or remain inserted in any earthed or earthed neutral conductor of a two wire-system or in any earthed or earthed neutral conductor of a multi-wire system or in any conductor connected thereto with the following exceptions: (a) A link for testing purposes, or (b) A switch for use in controlling a generator or transformer.

- **Danger Notices:**

1. The owner of every medium, high and extra-high voltage installation shall affix permanently in a conspicuous position a danger notice in Hindi or English and the local language of the district, with a sign of skull and Bones on
 - a) Every motor, generator, transformer and other electrical plant and equipment together with apparatus used for controlling or regulating the same;
 - b) All supports of high and extra-high voltage overhead lines which can be easily climb-upon without the aid of ladder or special appliances.

- **Cables:**

1. Flexible cables shall not be used for portable or transportable motors, generators, transformer rectifiers, electric drills, electric sprayers, welding sets or any other portable or transportable apparatus unless they are heavily insulated and adequately protected from mechanical injury.
2. Where the protection is by means of metallic covering, the covering shall be in metallic connection with the frame of any such apparatus and earth.
3. The cables shall be three core type and four-core type for portable and transportable apparatus working on single phase and three phases supply respectively and the wire meant to be used for ground connection shall be easily identifiable
4. Where A.C. and D.C. circuits are installed on the same support they shall be so arranged and protected that they shall not come into contact with each other when live.

- **Safety:**

1. Two or more gas masks shall be provided conspicuously and installed and maintained at accessible places in every generating station with capacity of 5 MW and above and enclosed

sub-station with transformation capacity of 5 MVA and above for use in the event of fire or smoke.

2. Provide that where more than one generator with capacity of 5 MW and above is installed in a power station, each generator would be provided with at least two separate gas masks in accessible and conspicuous position.

- **High Voltage Equipments installations**

1. High Voltage equipments shall have the IR value as stipulated in the relevant Indian Standard.
2. At a pressure of 1000 V applied between each live conductor and earth for a period of one minute the insulation resistance of HV installations shall be at least 1 Mega ohm Medium and Low Voltage Installations- At a pressure of 500 V applied between each live conductor and earth for a period of one minute, the insulation resistance of medium and low voltage installations shall be at least 1 Mega ohm

- **Every switchboard shall comply with the following provisions, namely:**

1. A clear space of not less than 1 meter in width shall be provided in front of the switchboard;
2. If there are any attachments or bare connections at the back of the switchboard, the space (if any) behind the switchboard shall be either less than 20 centimeters or more than 75 centimeters in width, measured from the farthest outstanding part of any attachment or conductor;
3. If the space behind the switchboard exceeds 75 centimeters in width, there shall be a passage-way from either end of the switchboard clear to a height of 1.8 meters.

- **Declared voltage of supply to consumer:**

1. In the case of low or medium voltage, by more than 6 per cent, or;
2. In the case of high voltage, by more than 6 per cent on the higher side or by more than 9 per cent on the lower side, or;
3. In the case of extra-high voltage, by more than 10 per cent on the higher side or by more than 12.5 per cent on the lower side.

- **Declared frequency of supply to consumer**

1. Except with the written consent of the consumer or with the previous sanction of the State Government a supplier shall not permit the frequency of an alternating current supply to vary from the declared frequency by more than 3 per cent.

- **Meters, maximum demand indicators and other apparatus on consumer's premises**

1. Any meter or maximum demand indicator or other apparatus placed upon a consumer's premises in accordance with section 26 shall be of appropriate capacity and shall be deemed to be correct if its limits of error are within the limits specified in the relevant Indian Standard Specification and where no such specification exists, the limits of error do not exceed 3 per cent above or below absolute accuracy at all loads in excess of one tenth of full load and up to full load Connection with earth Neutral conductor of a phase, 4 wire system and the middle conductor of a 2 phase, 3-wire system shall be earthed by not less than two separate and distinct connections with a minimum of two different earth electrodes of such large number as may be necessary to bring the earth resistance to a satisfactory value both at the generating

station and at the sub-station. The earth electrodes so provided, may be interconnected to reduce earth resistance. It may also be earthed at one or more points along the distribution system or service line in addition to any connection with earth which may be at the consumer's premises

2. In the case of a system comprising electric supply lines having concentric cables, the external conductor of such cables shall be earthed by two separate and distinct connections with earth.
3. The connection with earth may include a link by means of which the connection may be temporarily interrupted for the purpose of testing or for locating a fault.
4. All metal castings or metallic coverings containing or protecting any electric supply-line or apparatus shall be connected with earth and shall be so joined and connected across all junction boxes and other openings as to make good mechanical and electrical connection throughout their whole length.

- **Use of energy at high and extra-high voltage**

Voltage	Ground clearance	Sectional clearance
11KV	2.75 Meter	2.6 Meter
33KV	3.7 Meter	2.8 Meter
66KV	4.0 Meter	3.0 Meter
132KV	4.6 Meter	3.5 Meter
220KV	5.5 Meter	4.3 Meter
400KV	8.0 Meter	6.5 Meter

- **Transformer:**

1. Where transformer or transformers are used, suitable provision shall be made, either by connecting with earth a point of the circuit at the lower voltage or otherwise, to guard against danger by reason of the said circuit becoming Accidentally charged above its normal voltage by leakage from or contact with the circuit at the high voltage
2. A sub-station or a switch station with apparatus having more than 2000 liters of oil shall not be located in the basement where proper oil draining arrangement cannot be provided.
3. Where a sub-station or a switch station with apparatus having more than 2000 liters of oil is installed, whether indoor or out-doors, the following measures shall be taken, namely:—
4. The baffle walls [of 4 hour fire rating] shall be provided between the apparatus in the following cases:
 - (1) Single phase banks in the switch-yards of generating stations and substations;
 - (2) On the consumer premises;
 - (3) Where adequate clearance between the units is not available.
5. Provisions shall be made for suitable oil soak pit and where use of more than 9000 litres of oil in any one oil tank, receptacle or chamber is involved, provision shall be made for the draining away or removal of any oil which may leak or escape from the tanks receptacles or chambers containing the same.

6. The transformer shall be protected by an automatic high velocity water spray system or by carbon dioxide or BCF (Bromochlorodifluoromethane) or BTM (Bromo tri fluoromethane) fixed installation system;and
7. Oil filled transformers installed indoors shall not be on any floor above the ground or below the firstbasement.
8. Isolators and the corresponding earthing switches shall be interlocked so that no earthing switch can be closed unless and until the corresponding isolator is in openposition.
9. When two or more transformers are operated in parallel, the system shall be so arranged as to trip the secondary breaker of a transformer in case the primary breaker of that transformertrips.
10. Where two or more generators operate in parallel and neutral switching is adopted, inter-lock shall be provided to ensure that generator breaker cannot be closed unless one of the neutrals is connected to the earthingsystem.
11. Gas pressure type protection to given alarm and tripping shall be provided on all transformers of ratings 1000 KVA andabove.
12. Transformers of capacity 10 MVA and above shall be protected against incipient faults by differential protection; and All generators with rating of 100 KVA and above shall be protected against earth fault/leakage. All generators of rating 1000KVA and above shall be protected against faults within the generator winding using restricted earth fault protection or differential protection or byboth.

- **Connection withearth:**

1. In case of the delta connected system the neutral point shall be obtained by the insertion of a grounding transformer and current limiting resistance or impedance wherever considered necessary at the commencement of such asystem.
2. Where the earthing lead and earth connection are used only in connection with earthing guards erected under high or extra-high voltage overhead lines where they cross a telecommunication line or a railway line, and where such lines are equipped with earth leakage relays of a type and setting approved by the Inspector, the resistance shall not exceed 25ohms.

- **Clearance above ground of the lowestconductor**

1. No conductor of an overhead line, including service lines, erected across a street shall at any part thereof be at a height of lessthan:
2. For low and medium voltage lines 5.8meters
3. For high voltage lines 6.1meters
4. No conductor of an overhead line, including service lines, erected along any street shall at any part thereof be at a height lessthan:
5. For low and medium voltage lines 5.5meters
6. For high voltage lines 5.8meters
7. No conductor of in overhead line including service lines, erected elsewhere than along or across any street shall be at a height lessthan:
8. For low, medium and high voltages lines=4.6meters.
9. For low, medium and high voltage=4.0meters.
10. For high voltage lines above 11,000 volts=5.2meters.

11. For extra-high voltage lines the clearance above ground shall not be less than 5.2 meters plus 0.3 meter for every 33,000 volts or part thereof by which the voltage of the line exceeds 33,000 volts.

VARIOUS VOLTAGE LEVELS OF TRANSMISSION SYSTEMS:

All Users, RLDC, SLDC, State Transmission Utility (STU), Central Transmission Utility (CTU) and NLDC will have to take all possible measures to ensure that the grid voltage always remains within the following operating range.

Sr. No.	Nominal System Voltage (kV rms)	Maximum (kV rms)	Minimum (kV rms)
1.	765	800	728
2.	400	420	380
3.	220	245	198
4.	132	145	122
5.	110	121	99
6.	66	72	60
7.	33	36	30

The distribution segment continues to carry electricity from the point where transmission leaves off, that is, at the 66/33 kV level. The standard voltages on the distribution side are therefore 66kV, 33 kV, 22 kV, 11 kV and 400/230 volts, besides 6.6 kV, 3.3 kV and 2.2 kV. Depending upon the quantum of power and the distance involved, lines of appropriate voltages are laid. The main distribution equipment comprises HT and LT lines, transformers, substations, switchgears, capacitors, conductors and meters. HT lines supply electricity to industrial consumers while LT lines carry it to residential and commercial consumers.

Supply codes and Performance Standards lays down procedures for recovery of electricity charges, billing cycles, disconnections, and restoration of service and metering among other things. To protect consumer interests, the EA 2003 requires the SERCs to specify standards of performance for distribution license.